



Delaware Health and Social Services  
Division of Public Health Laboratory

30 Sunnyside Road  
Smyrna, Delaware 19977

RECEIVED

AUG 30 2019

OFFICE OF DRINKING WATER

<b>LIMS Report #:</b>	521721	<b>Date Collected:</b>	08/27/2019 11:38 am
<b>Agency:</b>	Office of Drinking Water	<b>Date Received:</b>	08/27/2019 2:15 pm
<b>Label ID (Sample #):</b>	S857289 (1181520)	<b>Collected By:</b>	KOERKEL, JOHN
<b>Property Owner/Facility:</b>	DS001	<b>Collector ID:</b>	2714
<b>PWSID:</b>	DE0000629		
<b>Water System Name:</b>	MILTON WATER DEPARTMENT		
<b>Sample Point:</b>	TCR_RT		
<b>Sample Location:</b>	113 CHANDLER ST MILTON HS	<b>Sampled pH:</b>	0.0
<b>Sample Type:</b>	RT	<b>Free Cl:</b>	0.36
<b>Chlorination:</b>	Chlorinated	<b>Total Cl:</b>	0.75
<b>Notes / Comments:</b>	pH 6.67		

**Specimen Note:**

Test	Result	Final Date
Free Cl at time of analysis	<0.1 mg/L	08/29/2019
Start Date and Time	08/27/2019 02:55:32 PM	08/29/2019
Stop Date and Time	08/28/2019 03:06:31 PM	08/29/2019
Colilert - E. coli	Absent	08/29/2019
Colilert - Total Coliforms	Absent	08/29/2019

Final



Delaware Health and Social Services  
Division of Public Health Laboratory **RECEIVED**

30 Sunnyside Road  
Smyrna, Delaware 19977

AUG 30 2019

<b>LIMS Report #:</b>	<b>521722</b>	<b>OFFICE OF DRINKING WATER</b>
<b>Agency:</b>	Office of Drinking Water	<b>Date Collected:</b> 08/27/2019 12:02 pm
<b>Label ID (Sample #):</b>	S857290 (1181523)	<b>Date Received:</b> 08/27/2019 2:16 pm
<b>Property Owner/Facility:</b>	DS001	<b>Collected By:</b> KOERKEL, JOHN
<b>PWSID:</b>	DE0000629	<b>Collector ID:</b> 2714
<b>Water System Name:</b>	MILTON WATER DEPARTMENT	
<b>Sample Point:</b>	TCR_RT	
<b>Sample Location:</b>	610 MULBERRY ST MILTON BS	<b>Sampled pH:</b> 0.0
<b>Sample Type:</b>	RT	<b>Free Cl:</b> 0.36
<b>Chlorination:</b>	Chlorinated	<b>Total Cl:</b> 0.41
<b>Notes / Comments:</b>	pH 6.72	

**Specimen Note:**

Test	Result	Final Date
Free Cl at time of analysis	<0.1 mg/L	08/29/2019
Start Date and Time	08/27/2019 02:55:32 PM	08/29/2019
Stop Date and Time	08/28/2019 03:06:31 PM	08/29/2019
Colilert - E. coli	Absent	08/29/2019
Colilert - Total Coliforms	Absent	08/29/2019

**Final**



Delaware Health and Social Services  
Division of Public Health Laboratory

30 Sunnyside Road  
Smyrna, Delaware 19977

RECEIVED

AUG 30 2019

OFFICE OF DRINKING WATER

<b>LIMS Report #:</b>	<b>621723</b>	<b>Date Collected:</b>	<b>08/27/2019 12:28 pm</b>
<b>Agency:</b>	<b>Office of Drinking Water</b>	<b>Date Received:</b>	<b>08/27/2019 2:17 pm</b>
<b>Label ID (Sample #):</b>	<b>S857291 (1181526)</b>	<b>Collected By:</b>	<b>KOERKEL, JOHN</b>
<b>Property Owner/Facility:</b>	<b>DS001</b>	<b>Collector ID:</b>	<b>2714</b>
<b>PWSID:</b>	<b>DE0000629</b>		
<b>Water System Name:</b>	<b>MILTON WATER DEPARTMENT</b>		
<b>Sample Point:</b>	<b>TCR_RT</b>		
<b>Sample Location:</b>	<b>701 FEDERAL ST MILTON KS</b>	<b>Sampled pH:</b>	<b>0.0</b>
<b>Sample Type:</b>	<b>RT</b>	<b>Free Cl:</b>	<b>0.39</b>
<b>Chlorination:</b>	<b>Chlorinated</b>	<b>Total Cl:</b>	<b>0.50</b>
<b>Notes / Comments:</b>	<b>pH 6.72</b>		

**Specimen Note:**

<b>Test</b>	<b>Result</b>	<b>Final Date</b>
Free Cl at time of analysis	<0.1 mg/L	08/29/2019
Start Date and Time	08/27/2019 02:55:32 PM	08/29/2019
Stop Date and Time	08/28/2019 03:06:31 PM	08/29/2019
Colilert - E. coli	Absent	08/29/2019
Colilert - Total Coliforms	Absent	08/29/2019

Final



Delaware Health and Social Services  
Division of Public Health Laboratory

30 Sunnyside Road  
Smyrna, Delaware 19977

RECEIVED

AUG 30 2019

OFFICE OF DRINKING WATER

**LIMS Report #:** 621724  
**Agency:** Office of Drinking Water  
**Label ID (Sample #):** S857292 (1181529)  
**Property Owner/Facility:** DS001  
**PWSID:** DE0000629  
**Water System Name:** MILTON WATER DEPARTMENT  
**Sample Point:** TCR\_RT  
**Sample Location:** 207 FRONT ST MILTON WELL 5  
SAMPLE PORT  
**Sample Type:** RT  
**Chlorination:** Not Chlorinated  
**Notes / Comments:** pH 6.73

**Date Collected:** 08/27/2019 12:45 pm  
**Date Received:** 08/27/2019 2:19 pm  
**Collected By:** KOERKEL, JOHN  
**Collector ID:** 2714

**Sampled pH:** 0.0  
**Free Cl:**  
**Total Cl:**

**Specimen Note:**

Test	Result	Final Date
Free Cl at time of analysis	<0.1 mg/L	08/29/2019
Start Date and Time	08/27/2019 02:55:32 PM	08/29/2019
Stop Date and Time	08/28/2019 03:06:31 PM	08/29/2019
Colilert - E. coli	Absent	08/29/2019
Colilert - Total Coliforms	Absent	08/29/2019

Final



Delaware Health and Social Services  
Division of Public Health Laboratory

30 Sunnyside Road  
Smyrna, Delaware 19977

RECEIVED

AUG 30 2019

OFFICE OF DRINKING WATER

**LIMS Report #:** 621780  
**Agency:** Office of Drinking Water  
**Label ID (Sample #):** S857288 (1181575)  
**Property Owner/Facility:** TP001  
**PWSID:** DE0000629  
**Water System Name:** MILTON WATER DEPARTMENT  
**Sample Point:** DEP001  
**Sample Location:** 113 CHANDLER ST MILTON DE 19968  
**Sample Type:** RT  
**Chlorination:** Chlorinated

**Date Collected:** 08/27/2019 11:28 am  
**Date Received:** 08/27/2019 2:46 pm  
**Collected By:** KOERKEL, JOHN  
**Collector ID:** 1004

**Sampled pH:** 6.67  
**Free Cl:** 0.36  
**Total Cl:** 0.75

**Specimen Note:**

Test	Result	MCL	Final Date
Sulfate	12.5 mg/L		08/29/2019
Chloride	23.5 mg/L		08/29/2019
Fluoride	0.3 mg/L	<=2.00	08/29/2019
Nitrite (as N)	<0.1 mg/L	<=1.000	08/29/2019
Nitrate (as N)	4.7 mg/L	<=10.00	08/29/2019

Final