



Delaware Health and Social Services
Division of Public Health Laboratory

30 Sunnyside Road
Smyrna, Delaware 19977

RECEIVED

AUG 01 2019

OFFICE OF DRINKING WATER

LIMS Report #:	516664	Date Collected:	07/29/2019 10:52 am
Agency:	Office of Drinking Water	Date Received:	07/29/2019 3:38 pm
Label ID (Sample #):	S857284 (1173725)	Collected By:	WILSON, ROBERT
Property Owner/Facility:	DS001	Collector ID:	3231
PWSID:	DE0000629		
Water System Name:	MILTON WATER DEPARTMENT		
Sample Point:	TCR_RT		
Sample Location:	113 CHANDLER ST MILTON YARD HYDRANT	Sampled pH:	0.0
Sample Type:	RT	Free Cl:	0.68
Chlorination:	Chlorinated	Total Cl:	1.37
Notes / Comments:	pH 6.82		

Specimen Note:

Test	Result	Final Date
Free Cl at time of analysis	<0.1 mg/L	07/31/2019
Start Date and Time	07/29/2019 03:44:50 PM	07/31/2019
Stop Date and Time	07/30/2019 03:47:52 PM	07/31/2019
Colilert - E. coli	Absent	07/31/2019
Colilert - Total Coliforms	Absent	07/31/2019

Final



Delaware Health and Social Services
Division of Public Health Laboratory

30 Sunnyside Road
Smyrna, Delaware 19977

RECEIVED

AUG 01 2019

OFFICE OF DRINKING WATER

LIMS Report #:	516865	Date Collected:	07/29/2019 12:44 pm
Agency:	Office of Drinking Water	Date Received:	07/29/2019 3:40 pm
Label ID (Sample #):	S857285 (1173726)	Collected By:	WILSON, ROBERT
Property Owner/Facility:	DS001	Collector ID:	3231
PWSID:	DE0000629		
Water System Name:	MILTON WATER DEPARTMENT		
Sample Point:	TCR_RT	Sampled pH:	0.0
Sample Location:	610 MULBERRY ST MILTON LBS	Free Cl:	0.44
Sample Type:	RT	Total Cl:	0.54
Chlorination:	Chlorinated		
Notes / Comments:	pH 6.79		

Specimen Note:

Test	Result	Final Date
Free Cl at time of analysis	<0.1 mg/L	07/31/2019
Start Date and Time	07/29/2019 03:44:50 PM	07/31/2019
Stop Date and Time	07/30/2019 03:47:52 PM	07/31/2019
Colilert - E. coli	Absent	07/31/2019
Colilert - Total Coliforms	Absent	07/31/2019

Final



Delaware Health and Social Services
Division of Public Health Laboratory
30 Sunnyside Road
Smyrna, Delaware 19977

RECEIVED

AUG 01 2019

OFFICE OF DRINKING WATER

LIMS Report #:	516666	Date Collected:	07/29/2019 1:45 pm
Agency:	Office of Drinking Water	Date Received:	07/29/2019 3:41 pm
Label ID (Sample #):	S857286 (1173727)	Collected By:	WILSON, ROBERT
Property Owner/Facility:	DS001	Collector ID:	3231
PWSID:	DE0000629		
Water System Name:	MILTON WATER DEPARTMENT		
Sample Point:	TCR_RT	Sampled pH:	0.0
Sample Location:	701 FRDERAL ST MILTON BS	Free Cl:	0.31
Sample Type:	RT	Total Cl:	0.43
Chlorination:	Chlorinated		
Notes / Comments:	pH 6.80		

Specimen Note:

Test	Result	Final Date
Free Cl at time of analysis	<0.1 mg/L	07/31/2019
Start Date and Time	07/29/2019 03:44:50 PM	07/31/2019
Stop Date and Time	07/30/2019 03:47:52 PM	07/31/2019
Colilert - E. coli	Absent	07/31/2019
Colilert - Total Coliforms	Absent	07/31/2019

Final



Delaware Health and Social Services
Division of Public Health Laboratory

30 Sunnyside Road
Smyrna, Delaware 19977

RECEIVED

AUG 01 2019

OFFICE OF DRINKING WATER

LIMS Report #:	516667	Date Collected:	07/29/2019 1:58 pm
Agency:	Office of Drinking Water	Date Received:	07/29/2019 3:43 pm
Label ID (Sample #):	S857287 (1173729)	Collected By:	WILSON, ROBERT
Property Owner/Facility:	52309	Collector ID:	3231
PWSID:	DE0000629		
Water System Name:	MILTON WATER DEPARTMENT		
Sample Point:	WT005	Sampled pH:	0.0
Sample Location:	207 FRONT ST SAMPLE TAP	Free Cl:	
Sample Type:	RT	Total Cl:	
Chlorination:	Not Chlorinated		

Specimen Note:

Test	Result	Final Date
Free Cl at time of analysis	<0.1 mg/L	07/31/2019
Start Date and Time	07/29/2019 03:44:50 PM	07/31/2019
Stop Date and Time	07/30/2019 03:47:52 PM	07/31/2019
Colilert - E. coli	Absent	07/31/2019
Colilert - Total Coliforms	Absent	07/31/2019

Final



Delaware Health and Social Services
Division of Public Health Laboratory

30 Sunnyside Road
Smyrna, Delaware 19977

RECEIVED

AUG 01 2019

OFFICE OF DRINKING WATER

LIMS Report #: 516668
Agency: Office of Drinking Water
Label ID (Sample #): S857283 (1173730)
Property Owner/Facility: TP001
PWSID: DE0000629
Water System Name: MILTON WATER DEPARTMENT
Sample Point: DEP001
Sample Location: 113 CHANDLER ST MILTON DE 19968
Sample Type: RT
Chlorination: Chlorinated

Date Collected: 07/29/2019 10:33 am
Date Received: 07/29/2019 3:47 pm
Collected By: WILSON, ROBERT
Collector ID: 3231

Sampled pH: 6.82
Free Cl: 0.65
Total Cl: 1.36

Specimen Note:

Test	Result	MCL	Final Date
Sulfate	13.0 mg/L		07/31/2019
Chloride	23.6 mg/L		07/31/2019
Fluoride	0.2 mg/L	<=2.00	07/31/2019
Nitrite (as N)	<0.1 mg/L	<=1.000	07/31/2019
Nitrate (as N)	4.8 mg/L	<=10.00	07/31/2019

Final