



Delaware Health and Social Services
Division of Public Health Laboratory

30 Sunnyside Road
Smyrna, Delaware 19977

RECEIVED

JUN 03 2019

OFFICE OF DRINKING WATER

LIMS Report #:	506616	Date Collected:	05/29/2019 11:57 am
Agency:	Office of Drinking Water	Date Received:	05/29/2019 3:20 pm
Label ID (Sample #):	S741105 (1158528)	Collected By:	WILSON, ROBERT
Property Owner/Facility:	TP001	Collector ID:	3231
PWSID:	DE0000629		
Water System Name:	MILTON WATER DEPARTMENT		
Sample Point:	DEP001		
Sample Location:	113 CHANDLER ST MILTON DE 19968	Sampled pH:	6.90
Sample Type:	RT	Free Cl:	0.79
Chlorination:	Chlorinated	Total Cl:	1.66

Specimen Note:

Test	Result	MCL	Final Date
Sulfate	13.6 mg/L		05/31/2019
Chloride	23.5 mg/L		05/31/2019
Fluoride	0.2 mg/L	<=2.00	05/31/2019
Nitrite (as N)	<0.1 mg/L	<=1.000	05/31/2019
Nitrate (as N)	4.9 mg/L	<=10.00	05/31/2019

Final



Delaware Health and Social Services
Division of Public Health Laboratory

30 Sunnyside Road
Smyrna, Delaware 19977

RECEIVED

JUN 03 2019

OFFICE OF DRINKING WATER

LIMS Report #:	508610	Date Collected:	05/29/2019 12:16 pm
Agency:	Office of Drinking Water	Date Received:	05/29/2019 2:59 pm
Label ID (Sample #):	S741106 (1158513)	Collected By:	WILSON, ROBERT
Property Owner/Facility:	DS001	Collector ID:	3231
PWSID:	DE0000629		
Water System Name:	MILTON WATER DEPARTMENT		
Sample Point:	TCR_RT		
Sample Location:	113 CHANDLER ST MILTON DE 19968	Sampled pH:	0.0
Sample Type:	RT	Free Cl:	0.82
Chlorination:	Chlorinated	Total Cl:	1.61

Specimen Note:

Test	Result	Final Date
Free Cl at time of analysis	<0.1 mg/L	05/31/2019
Incubation Start	05/29/2019 03:30:00 PM	05/31/2019
Incubation Stop	05/30/2019 03:31:00 PM	05/31/2019
Colisure - Total Coliforms	Absent	05/31/2019
Colisure - E. coli	Absent	05/31/2019

Final



Delaware Health and Social Services
Division of Public Health Laboratory

30 Sunnyside Road
Smyrna, Delaware 19977

RECEIVED

JUN 03 2019

OFFICE OF DRINKING WATER

LIMS Report #:	506611	Date Collected:	05/29/2019 12:55 pm
Agency:	Office of Drinking Water	Date Received:	05/29/2019 3:01 pm
Label ID (Sample #):	S741107 (1158515)	Collected By:	WILSON, ROBERT
Property Owner/Facility:	DS001	Collector ID:	3231
PWSID:	DE0000629		
Water System Name:	MILTON WATER DEPARTMENT		
Sample Point:	TCR_RT		
Sample Location:	610 MULBERRY ST MILTON DE 19965 LBS	Sampled pH:	0.0
Sample Type:	RT	Free Cl:	0.53
Chlorination:	Chlorinated	Total Cl:	0.72

Specimen Note:

Test	Result	Final Date
Free Cl at time of analysis	<0.1 mg/L	05/31/2019
Incubation Start	05/29/2019 03:30:00 PM	05/31/2019
Incubation Stop	05/30/2019 03:31:00 PM	05/31/2019
Colisure - Total Coliforms	Absent	05/31/2019
Colisure - E. coli	Absent	05/31/2019

Final



Delaware Health and Social Services
Division of Public Health Laboratory

30 Sunnyside Road
Smyrna, Delaware 19977

RECEIVED

JUN 03 2019

OFFICE OF DRINKING WATER

LIMS Report #:	506612	Date Collected:	05/29/2019 1:15 pm
Agency:	Office of Drinking Water	Date Received:	05/29/2019 3:02 pm
Label ID (Sample #):	S741108 (1158516)	Collected By:	WILSON, ROBERT
Property Owner/Facility:	DS001	Collector ID:	3231
PWSID:	DE0000629		
Water System Name:	MILTON WATER DEPARTMENT		
Sample Point:	TCR_RT		
Sample Location:	701 FEDERAL ST MILTON DE 19968 BS	Sampled pH:	0.0
Sample Type:	RT	Free Cl:	0.49
Chlorination:	Chlorinated	Total Cl:	0.64

Specimen Note:

Test	Result	Final Date
Free Cl at time of analysis	<0.1 mg/L	05/31/2019
Incubation Start	05/29/2019 03:30:00 PM	05/31/2019
Incubation Stop	05/30/2019 03:31:00 PM	05/31/2019
Colisure - Total Coliforms	Absent	05/31/2019
Colisure - E. coli	Absent	05/31/2019

Final



Delaware Health and Social Services
Division of Public Health Laboratory **RECEIVED**
30 Sunnyside Road
Smyrna, Delaware 19977
JUN 03 2019

OFFICE OF DRINKING WATER

LIMS Report #: 606613
Agency: Office of Drinking Water
Label ID (Sample #): S741109 (1158517)
Property Owner/Facility: 52309
PWSID: DE0000629
Water System Name: MILTON WATER DEPARTMENT
Sample Point: WT005
Sample Location: 207 FRONT ST MILTON DE 19968
Sample Type: RT
Chlorination: Not Chlorinated

Date Collected: 05/29/2019 1:29 pm
Date Received: 05/29/2019 3:03 pm
Collected By: WILSON, ROBERT
Collector ID: 3231

Sampled pH: 0.0
Free Cl:
Total Cl:

Specimen Note:

Test	Result	Final Date
Free Cl at time of analysis	<0.1 mg/L	05/31/2019
Incubation Start	05/29/2019 03:30:00 PM	05/31/2019
Incubation Stop	05/30/2019 03:31:00 PM	05/31/2019
Colisure - Total Coliforms	Absent	05/31/2019
Colisure - E. coli	Absent	05/31/2019

Final



Delaware Health and Social Services
Division of Public Health Laboratory

30 Sunnyside Road
Smyrna, Delaware 19977

Phone: (302) 223-1520 Fax: (302) 653-2877

RECEIVED

MAY 06 2019

OFFICE OF DRINKING WATER

LIMS Report #: 501410
Agency: Office of Drinking Water
Label ID (Sample #): S741103 (1151814)
Property Owner/Facility: DS001
PWSID: DE0000629
Water System Name: MILTON WATER DEPARTMENT
Sample Point: TCR_SP
Sample Location: 113 CHANDLER ST (WELL 7)
Sample Type: SP
Chlorination: Not Chlorinated
Notes / Comments: pH 7.22

Date Collected: 05/02/2019 10:20 am
Date Received: 05/02/2019 12:55 pm
Collected By: KOERKEL, JOHN
Collector ID: 2714

Sampled pH: 0.0
Free Cl:
Total Cl:

Specimen Note:

Test	Result	Final Date
Free Cl at time of analysis	<0.1 mg/L	05/03/2019
Incubation Start	05/02/2019 01:21:00 PM	05/03/2019
Incubation Stop	05/03/2019 08:35:00 AM	05/03/2019
Colilert 18 - Total Coliforms	Absent	05/03/2019
Colilert 18 - E. coli	Absent	05/03/2019

Final