

# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 12/23/2019 9:46 AM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 12/23/2019

Sampling Pt: TCR\_RT

Redacted

Address: OT 113 CHANDLER ST (TREATMENT PLANT)

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S895758

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.65

### Field Results

Free Chlorine: 0.310

Total Chlorine: 0.690

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100 COLIFORM (TCR)	9223B-PA	12/23/2019 3:35 PM	12/24/2019 3:36 PM	12/31/2019

Detection: Absent

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014 E. COLI	9223B-PA	12/23/2019 3:35 PM	12/24/2019 3:36 PM	12/31/2019

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 12/23/2019 9:46 AM  
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 12/23/2019  
Sampling Pt: TCR\_RT Redacted  
Address: OT 113 CHANDLER ST (TREATMENT PLANT)  
Sample Type: ROUTINE For Compliance: Yes  
Lab Sample No: S895758 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY  
State Sample No: pH 6.65

---

# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 12/23/2019 10:29 AM

Facility Source/Plant: DS001

DISTRIBUTION SYSTEM

Lab Received: 12/23/2019

Sampling Pt: TCR\_RT

Redacted

Address: BS 611 MULBERRY ST

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S895759

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.67

Field Results Free Chlorine: 0.330

Total Chlorine: 0.480

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	12/23/2019 3:35 PM	12/24/2019 3:36 PM	12/31/2019

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	12/23/2019 3:35 PM	12/24/2019 3:36 PM	12/31/2019

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 12/23/2019 10.29 AM  
Facility Source/Plant: DS001 DISTRIBUTION SYSTEM Lab Received: 12/23/2019  
Sampling Pt: TCR\_RT Redacted  
Address: BS 611 MULBERRY ST  
Sample Type: ROUTINE For Compliance: Yes  
Lab Sample No: S895759 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY  
State Sample No: pH 6.67

---

# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 12/23/2019 10:52 AM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 12/23/2019

Sampling Pt: TCR\_RT

Redacted

Address: KS 701 FEDERAL ST

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S895760

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.65

Field Results Free Chlorine: 0.360

Total Chlorine: 0.530

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100 COLIFORM (TCR)	9223B-PA	12/23/2019 3:35 PM	12/24/2019 3:36 PM	12/31/2019

Detection: Absent

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014 E. COLI	9223B-PA	12/23/2019 3:35 PM	12/24/2019 3:36 PM	12/31/2019

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 12/23/2019 10.52 AM  
Facility Source/Plant: DS001 DISTRIBUTION SYSTEM Lab Received: 12/23/2019  
Sampling Pt: TCR\_RT Redacted  
Address: KS 701 FEDERAL ST  
Sample Type: ROUTINE For Compliance: Yes  
Lab Sample No: S895760 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY  
State Sample No: pH 6.65

---

# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 12/23/2019 11:08 AM

Facility Source/Plant: DS001

DISTRIBUTION SYSTEM

Lab Received: 12/23/2019

Sampling Pt: TCR\_RT

Redacted

Address: WELL #5 SAMPLE POINT 207 FRONT ST (PUMP HOUSE #5)

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S895761

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 5.82

RESULT	Analyte	Method	Analysis Start and End Dates		State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	12/23/2019	3:35 PM	12/24/2019	3:36 PM

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates		State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	12/23/2019	3:35 PM	12/24/2019	3:36 PM

Detection: Absent

# Drinking Water Watch

## Inorganic Chemicals Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 12/23/2019 9:46 AM

Facility Source/Plant: TP001

WELL #2, 3 & 4 TREATMENT PLANT

Lab Received: 12/23/2019

Sampling Pt: DEP001

Redacted

Address: 113 CHANDLER ST (TREATMENT PLANT)

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S895757

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

### Field Results

Free Chlorine: 0.310

Total Chlorine: 0.690

pH: 6.7

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1055	SULFATE	300.0	12/26/2019 8:39 AM	12/26/2019 8:39 AM	12/31/2019
Detection: 12.3316 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1041	NITRITE	300.0	12/26/2019 8:39 AM	12/26/2019 8:39 AM	12/31/2019
Detection: < 0.1 MG/L					



Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 12/23/2019 9.46 AM  
 Facility Source/Plant: TP001 WELL #2, 3 & 4 TREATMENT PLANT Lab Received: 12/23/2019  
 Sampling Pt: DEP001 Redacted  
 Address: 113 CHANDLER ST (TREATMENT PLANT)  
 Sample Type: ROUTINE For Compliance: Yes  
 Lab Sample No: S895757 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY  
 State Sample No:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1040	NITRATE	300.0	12/26/2019 8.39 AM	12/26/2019 8.39 AM	12/31/2019
Detection: 4.8518 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1025	FLUORIDE	300.0	12/26/2019 8.39 AM	12/26/2019 8.39 AM	12/31/2019
Detection: 0.1696 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1017	CHLORIDE	300.0	12/26/2019 8.39 AM	12/26/2019 8.39 AM	12/31/2019
Detection: 23.6848 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1038	NITRATE-NITRITE				
Detection: 4.8518 MG/L					

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 12/23/2019 9.46 AM  
Facility Source/Plant: TP001 WELL #2, 3 & 4 TREATMENT PLANT Lab Received: 12/23/2019  
Sampling Pt: DEP001 Redacted  
Address: 113 CHANDLER ST (TREATMENT PLANT)  
Sample Type: ROUTINE For Compliance: Yes  
Lab Sample No: S895757 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY  
State Sample No:

---