



Delaware Health and Social Services
Division of Public Health Laboratory
30 Sunnyside Road
Smyrna, Delaware 19977

RECEIVED

APR 22 2020

OFFICE OF DRINKING WATER

LIMS Report #: 568874
Agency: Office of Drinking Water
Label ID (Sample #): S895793 (1244140)
Property Owner/Facility: DS001
PWSID: DE0000629
Water System Name: MILTON WATER DEPARTMENT
Sample Point: TCR_RT
Sample Location: 207 FRONT ST MILTON WELL # 5
SAMPLE POINT
Sample Type: RT
Chlorination: Not Chlorinated
Notes / Comments: pH 5.40

Date Collected: 04/21/2020 10 40 am
Date Received: 04/21/2020 12 48 pm
Collected By: KOERKEL, JOHN
Collector ID: 2714

Sampled pH: 0.0
Free Cl:
Total Cl:

Specimen Note:

Test	Result	Final Date
Colilert - E. coli	Absent	04/22/2020
Colilert - Total Coliforms	Absent	04/22/2020
Free Cl at time of analysis	<0.1 mg/L	04/22/2020
Start Date and Time	04/21/2020 01 50 00 PM	04/22/2020
Stop Date and Time	04/22/2020 01 57 00 PM	04/22/2020

Final



Delaware Health and Social Services
Division of Public Health Laboratory

30 Sunnyside Road
Smyrna, Delaware 19977

RECEIVED

APR 22 2020

OFFICE OF DRINKING WATER

LIMS Report #: 568873
Agency: Office of Drinking Water
Label ID (Sample #): S741116 (1244138)
Property Owner/Facility: DS001
PWSID: DE0000629
Water System Name: MILTON WATER DEPARTMENT
Sample Point: TCR_RT
Sample Location: 210 FRONT ST MILTON US
Sample Type: RT
Chlorination: Chlorinated
Notes / Comments: pH 6.70

Date Collected: 04/21/2020 10 20 am
Date Received: 04/21/2020 12 47 pm
Collected By: KOERKEL, JOHN
Collector ID: 2714

Sampled pH: 0.0
Free Cl: 0.41
Total Cl: 0.46

Specimen Note:

Test	Result	Final Date
Colilert - E. coli	Absent	04/22/2020
Colilert - Total Coliforms	Absent	04/22/2020
Free Cl at time of analysis	<0.1 mg/L	04/22/2020
Start Date and Time	04/21/2020 01 50 00 PM	04/22/2020
Stop Date and Time	04/22/2020 01 57 00 PM	04/22/2020

Final



Delaware Health and Social Services
Division of Public Health Laboratory

30 Sunnyside Road
Smyrna, Delaware 19977

RECEIVED

APR 22 2020

OFFICE OF DRINKING WATER

LIMS Report #: 568872
Agency: Office of Drinking Water
Label ID (Sample #): S741115 (1244137)
Property Owner/Facility: DS001
PWSID: DE0000629
Water System Name: MILTON WATER DEPARTMENT
Sample Point: TCR_RT
Sample Location: 701 FEDERAL ST MILTON KS
Sample Type: RT
Chlorination: Chlorinated
Notes / Comments: pH 6.70

Date Collected: 04/21/2020 9 55 am
Date Received: 04/21/2020 12 46 pm
Collected By: KOERKEL, JOHN
Collector ID: 2714

Sampled pH: 0.0
Free Cl: 0.41
Total Cl: 0.49

Specimen Note:

Test	Result	Final Date
Colilert - E. coli	Absent	04/22/2020
Colilert - Total Coliforms	Absent	04/22/2020
Free Cl at time of analysis	<0.1 mg/L	04/22/2020
Start Date and Time	04/21/2020 01 50 00 PM	04/22/2020
Stop Date and Time	04/22/2020 01 57 00 PM	04/22/2020

Final



Delaware Health and Social Services
Division of Public Health Laboratory
30 Sunnyside Road
Smyrna, Delaware 19977

RECEIVED

APR 22 2020

OFFICE OF DRINKING WATER

LIMS Report #:	568871	Date Collected:	04/21/2020 9:36 am
Agency:	Office of Drinking Water	Date Received:	04/21/2020 12:44 pm
Label ID (Sample #):	S741122 (1244136)	Collected By:	KOERKEL, JOHN
Property Owner/Facility:	DS001	Collector ID:	2714
PWSID:	DE0000629		
Water System Name:	MILTON WATER DEPARTMENT		
Sample Point:	TCR_RT	Sampled pH:	0.0
Sample Location:	610 MULBERRY ST MILTON BS	Free Cl:	0.33
Sample Type:	RT	Total Cl:	0.39
Chlorination:	Chlorinated		
Notes / Comments:	pH 6.72		

Specimen Note:

Test	Result	Final Date
Colilert - E. coli	Absent	04/22/2020
Colilert - Total Coliforms	Absent	04/22/2020
Free Cl at time of analysis	<0.1 mg/L	04/22/2020
Start Date and Time	04/21/2020 01:50:00 PM	04/22/2020
Stop Date and Time	04/22/2020 01:57:00 PM	04/22/2020

Final



Delaware Health and Social Services
Division of Public Health Laboratory

30 Sunnyside Road
Smyrna, Delaware 19977

RECEIVED

APR 22 2020

OFFICE OF DRINKING WATER

LIMS Report #: 568870
Agency: Office of Drinking Water
Label ID (Sample #): S741121 (1244135)
Property Owner/Facility: DS001
PWSID: DE0000629
Water System Name: MILTON WATER DEPARTMENT
Sample Point: TCR_RT
Sample Location: 113 CHANDLER ST MILTON OT
Sample Type: RT
Chlorination: Chlorinated
Notes / Comments: pH 6.70

Date Collected: 04/21/2020 9:16 am
Date Received: 04/21/2020 12:43 pm
Collected By: KOERKEL, JOHN
Collector ID: 2714

Sampled pH: 0.0
Free Cl: 0.45
Total Cl: 0.70

Specimen Note:

Test	Result	Final Date
Colilert - E. coli	Absent	04/22/2020
Colilert - Total Coliforms	Absent	04/22/2020
Free Cl at time of analysis	<0.1 mg/L	04/22/2020
Start Date and Time	04/21/2020 01:50:00 PM	04/22/2020
Stop Date and Time	04/22/2020 01:57:00 PM	04/22/2020

Final



RECEIVED
APR 22 2020

Delaware Health and Social Services
Division of Public Health Laboratory
30 Sunnyside Road
Smyrna, Delaware 19977

OFFICE OF DRINKING WATER

LIMS Report #:	568885	Date Collected:	04/21/2020 9:15 am
Agency:	Office of Drinking Water	Date Received:	04/21/2020 1:18 pm
Label ID (Sample #):	S741120 (1244158)	Collected By:	KOERKEL, JOHN
Property Owner/Facility:	TP001	Collector ID:	2714
PWSID:	DE0000629		
Water System Name:	MILTON WATER DEPARTMENT		
Sample Point:	DEP001		
Sample Location:	113 CHANDLER ST MILTON DE 19968	Sampled pH:	6.70
Sample Type:	RT	Free Cl:	.45
Chlorination:	Chlorinated	Total Cl:	.70

Specimen Note:

Test	Result	MCL	Final Date
Fluoride	0.2 mg/L	<=2.00	04/22/2020
Nitrite (as N)	<0.1 mg/L	<=1.000	04/22/2020
Nitrate (as N)	4.9 mg/L	<=10.00	04/22/2020
Chloride	25.2 mg/L		04/22/2020
Sulfate	12.8 mg/L		04/22/2020

Final