

# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 08/27/2020 9.27 AM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 08/27/2020

Sampling Pt: TCR\_RT

Redacted

Address: 113 CHANDLER ST MILTON DE OT

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S895612

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.75

### Field Results

Free Chlorine: 0.660

Total Chlorine: 1.010

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3100 COLIFORM (TCR)

9223B-PA

08/28/2020 1.59 PM 08/28/2020 2.00 PM

08/30/2020

Detection: Absent

RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3014 E. COLI

9223B-PA

08/28/2020 1.59 PM 08/28/2020 2.00 PM

08/30/2020

Detection: Absent

Water System: DE00000629 MILTON WATER DEPARTMENT Sample Collected: 08/27/2020 9.27 AM  
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 08/27/2020  
Sampling Pt: TCR\_RT Redacted  
Address: 113 CHANDLER ST MILTON DE OT  
Sample Type: ROUTINE For Compliance: Yes  
Lab Sample No: S895612 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY  
State Sample No: pH 6.75

---

# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT  
DISTRIBUTION SYSTEM

Sample Collected: 08/27/2020 9.27 AM

Facility Source/Plant : DS001

Redacted

Lab Received: 08/27/2020

Sampling Pt: TCR\_RT

Redacted

Address: 113 CHANDLER ST MILTON DE OT

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S895612

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.75

### Field Results

Free Chlorine: 0.660

Total Chlorine: 1.010

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	08/28/2020 1.59 PM - 08/28/2020 2.00 PM	08/30/2020	

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	08/28/2020 1.59 PM - 08/28/2020 2.00 PM	08/30/2020	

Detection: Absent

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 08/27/2020 9.27 AM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 08/27/2020

Sampling Pt: TCR\_RT  
Address: 113 CHANDLER ST MILTON DE OT  
Redacted

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S895612

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.75

# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 08/27/2020 9.45 AM

Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 08/27/2020

Sampling Pt: TCR\_RT Redacted

Address: 610 MULBERRY ST MILTON DE BS

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S895613 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.76

Field Results Free Chlorine: 0.330 Total Chlorine: 0.610

pH: Temperature:

Flow Rate: Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	08/28/2020 1.59 PM - 08/28/2020 2.00 PM	08/30/2020	

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	08/28/2020 1.59 PM - 08/28/2020 2.00 PM	08/30/2020	

Detection: Absent

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 08/27/2020 9.45 AM

Facility Source/Plant: DS001

DISTRIBUTION SYSTEM

Lab Received: 08/27/2020

Sampling Pt: TCR\_RT

Redacted

Address: 610 MULBERRY ST MILTON DE BS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S895613

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

PH 6.76

# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT  
DISTRIBUTION SYSTEM

Sample Collected: 08/27/2020 9.45 AM

Facility Source/Plant: DS001

Redacted

Lab Received: 08/27/2020

Sampling Pt: TCR\_RT

Redacted

Address: 610 MULBERRY ST MILTON DE BS

Sample Type: ROUTINE

For Compliance: Yes

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

Lab Sample No: S895613

State Sample No: PH 6.76

### Field Results

Free Chlorine: 0.330

Total Chlorine: 0.610

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	08/28/2020 1.59 PM - 08/28/2020 2.00 PM	08/30/2020	
Detection: Absent					
3014	E. COLI	9223B-PA	08/28/2020 1.59 PM - 08/28/2020 2.00 PM	08/30/2020	
Detection: Absent					

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 08/27/2020 9.45 AM  
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 08/27/2020  
Sampling Pt: TCR\_RT Redacted  
Address: 610 MULBERRY ST MILTON DE BS  
Sample Type: ROUTINE  
Lab Sample No: S895613  
State Sample No: For Compliance: Yes  
pH 6.76 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

---



# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT  
DISTRIBUTION SYSTEM

Sample Collected: 08/27/2020 10.28 AM

Facility Source/Plant : DS001

Redacted

Lab Received: 08/27/2020

Sampling Pt: TCR\_RT

701 FECERAL ST MILTON DE KS

Address:

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S895614

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.78

### Field Results

Free Chlorine: 0.340

Total Chlorine: 0.630

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3100 COLIFORM (TCR)

9223B-PA

08/28/2020 1.59 PM 08/28/2020 2.00 PM

08/30/2020

Detection: Absent

RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3014 E. COLI

9223B-PA

08/28/2020 1.59 PM 08/28/2020 2.00 PM

08/30/2020

Detection: Absent

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 08/27/2020

10.28 AM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 08/27/2020

Sampling Pt: TCR\_RT

Redacted

Address: 701 FECERAL ST MILTON DE KS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S895614

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

PH 6.78

# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT  
DISTRIBUTION SYSTEM

Sample Collected: 08/27/2020 10.28 AM

Facility Source/Plant : DS001

Redacted

Lab Received: 08/27/2020

Sampling Pt: TCR\_RT

Redacted

Address: 701 FECERAL ST MILTON DE KS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S895614

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.78

### Field Results

Free Chlorine: 0.340

Total Chlorine: 0.630

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	08/28/2020 1.59 PM - 08/28/2020 2.00 PM	08/30/2020	

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	08/28/2020 1.59 PM - 08/28/2020 2.00 PM	08/30/2020	

Detection: Absent

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 08/27/2020

10.28 AM

Facility Source/Plant: DS001

DISTRIBUTION SYSTEM

Lab Received: 08/27/2020

Sampling Pt: TCR\_RT

Redacted

Address: 701 FECERAL ST MILTON DE KS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S895614

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

PH 6.78

---

# Drinking Water Watch

## Inorganic Chemicals Sample Report

**Water System:** DE0000629      **MILTON WATER DEPARTMENT**      **Sample Collected:** 08/27/2020      9:25 AM  
**Facility Source/Plant:** TP001      **WELL #2, 3 & 4 TREATMENT PLANT**      **Lab Received:** 08/27/2020  
**Sampling Pt:** DEP001      **Redacted**  
**Address:** 113 CHANDLER ST MILTON DE  
**Sample Type:** ROUTINE      **For Compliance:** Yes  
**Lab Sample No:** S895611      **Laboratory:** DE017      **DELAWARE PUBLIC HEALTH LABORATORY**  
**State Sample No:**

**Field Results**      **Free Chlorine:** 0.660      **Total Chlorine:** 1.010  
**pH:** 6.8      **Temperature:**  
**Flow Rate:**      **Turbidity:**

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1055	SULFATE	300.0	08/28/2020 9:20 AM - 08/28/2020 9:20 AM	08/31/2020	
<b>Detection:</b> 11.9554 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1041	NITRITE	300.0	08/28/2020 9:20 AM - 08/28/2020 9:20 AM	08/31/2020	
<b>Detection:</b> < 0.1 MG/L					

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 08/27/2020 9.25 AM  
 Facility Source/Plant : TP001 WELL #2, 3 & 4 TREATMENT PLANT Lab Received: 08/27/2020  
 Sampling Pt: DEP001 Redacted  
 Address: 113 CHANDLER ST MILTON DE  
 Sample Type: ROUTINE For Compliance: Yes  
 Lab Sample No: S895611 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY  
 State Sample No:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1040	NITRATE	300.0	08/28/2020 9.20 AM - 08/28/2020 9.20 AM	08/31/2020	
Detection: 5.0417 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1025	FLUORIDE	300.0	08/28/2020 9.20 AM - 08/28/2020 9.20 AM	08/31/2020	
Detection: 0.1787 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1017	CHLORIDE	300.0	08/28/2020 9.20 AM - 08/28/2020 9.20 AM	08/31/2020	
Detection: 25.3611 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1038	NITRATE-NITRITE				
Detection: 5.0417 MG/L					

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 08/27/2020 9.25 AM  
Facility Source/Plant: TP001 WELL #2, 3 & 4 TREATMENT PLANT Lab Received: 08/27/2020  
Sampling Pt: DEP001 Redacted  
Address: 113 CHANDLER ST MILTON DE  
Sample Type: ROUTINE For Compliance: Yes  
Lab Sample No: S895611 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY  
State Sample No:

---