

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 07/29/2020 9.10 AM

Facility Source/Plant: DS001 DISTRIBUTION SYSTEM Lab Received: 07/29/2020

Sampling Pt: TCR_RT Redacted

Address: 113 CHANDLER ST MILTON OT

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S925776 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.72

Field Results Free Chlorine: 0.410 Total Chlorine: 1.320

pH: Temperature:

Flow Rate: Turbidity:

RESULT Analyte Method Analysis Start and End Dates State Notified On PWS Notified On

3100 COLIFORM (TCR) 9223B-PA 07/30/2020 1.50 PM 07/30/2020 1.50 PM 07/31/2020

Detection: Absent

RESULT Analyte Method Analysis Start and End Dates State Notified On PWS Notified On

3014 E. COLI 9223B-PA 07/30/2020 1.50 PM 07/30/2020 1.50 PM 07/31/2020

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 07/29/2020 9.10 AM
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 07/29/2020
Sampling Pt: TCR_RT Redacted
Address: 113 CHANDLER ST MILTON OT
Sample Type: ROUTINE
Lab Sample No: S925776
State Sample No: For Compliance: Yes
Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
pH 6.72

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT
DISTRIBUTION SYSTEM

Sample Collected: 07/29/2020 9.10 AM

Facility Source/Plant : DS001

Redacted

Lab Received: 07/29/2020

Sampling Pt: TCR_RT

Redacted

Address: 113 CHANDLER ST MILTON OT

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925776

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.72

Field Results

Free Chlorine: 0.410

Total Chlorine: 1.320

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3100 COLIFORM (TCR)

9223B-PA

07/30/2020 1.50 PM 07/30/2020 1.50 PM

07/31/2020

Detection: Absent

RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3014 E. COLI

9223B-PA

07/30/2020 1.50 PM 07/30/2020 1.50 PM

07/31/2020

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 07/29/2020 9.10 AM
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 07/29/2020
Sampling Pt: TCR_RT Redacted
Address: 113 CHANDLER ST MILTON OT
Sample Type: ROUTINE
Lab Sample No: S925776
State Sample No: For Compliance: Yes
Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
pH 6.72

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT
DISTRIBUTION SYSTEM

Sample Collected: 07/29/2020 10:36 AM

Facility Source/Plant: DS001

Redacted

Lab Received: 07/29/2020

Sampling Pt: TCR_RT

610 MULBERRY ST MILTON BS

Address:

ROUTINE

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925778

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.72

Field Results

Free Chlorine: 0.330

Total Chlorine: 0.750

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	07/30/2020 1:50 PM	07/30/2020 1:50 PM	07/31/2020

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	07/30/2020 1:50 PM	07/30/2020 1:50 PM	07/31/2020

Detection: Absent

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 07/29/2020

10.36 AM

Facility Source/Plant: DS001

DISTRIBUTION SYSTEM

Lab Received: 07/29/2020

Sampling Pt: TCR_RT

Redacted

Address: 610 MULBERRY ST MILTON BS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925778

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.72

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 07/29/2020 10.36 AM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 07/29/2020

Sampling Pt: TCR_RT

Redacted

Address: 610 MULBERRY ST MILTON BS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925778

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.72

Field Results

Free Chlorine: 0.330

Total Chlorine: 0.750

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3100 COLIFORM (TCR)

9223B-PA

07/30/2020 1.50 PM 07/30/2020 1.50 PM

07/31/2020

Detection: Absent

RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3014 E. COLI

9223B-PA

07/30/2020 1.50 PM 07/30/2020 1.50 PM

07/31/2020

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 07/29/2020 10.36 AM
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 07/29/2020
Sampling Pt: TCR_RT Redacted
Address: 610 MULBERRY ST MILTON BS
Sample Type: ROUTINE For Compliance: Yes
Lab Sample No: S925778 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
State Sample No: pH 6.72

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT
DISTRIBUTION SYSTEM

Sample Collected: 07/29/2020 10:55 AM

Facility Source/Plant: DS001

Redacted

Lab Received: 07/29/2020

Sampling Pt: TCR_RT

Redacted

Address: 701 FEDERAL ST MILTON BS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925779

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.72

Field Results

Free Chlorine: 0.310

Total Chlorine: 0.620

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3100 COLIFORM (TCR)

9223B-PA

07/30/2020 1:50 PM 07/30/2020 1:50 PM

07/31/2020

Detection: Absent

RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3014 E. COLI

9223B-PA

07/30/2020 1:50 PM 07/30/2020 1:50 PM

07/31/2020

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 07/29/2020 10.55 AM
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 07/29/2020
Sampling Pt: TCR_RT Redacted
Address: 701 FEDERAL ST MILTON BS
Sample Type: ROUTINE For Compliance: Yes
Lab Sample No: S925779 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
State Sample No:
PH 6.72

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT
DISTRIBUTION SYSTEM

Sample Collected: 07/29/2020 10:55 AM

Facility Source/Plant: DS001

Redacted

Lab Received: 07/29/2020

Sampling Pt: TCR_RT

Redacted

Address: 701 FEDERAL ST MILTON BS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925779

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.72

Field Results

Free Chlorine: 0.310

Total Chlorine: 0.620

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3100 COLIFORM (TCR)

9223B-PA

07/30/2020 1:50 PM 07/30/2020 1:50 PM

07/31/2020

Detection: Absent

RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3014 E. COLI

9223B-PA

07/30/2020 1:50 PM 07/30/2020 1:50 PM

07/31/2020

Detection: Absent

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 07/29/2020 10.55 AM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 07/29/2020

Sampling Pt: TCR_RT

Redacted

Address: 701 FEDERAL ST MILTON BS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925779

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

PH 6.72

Drinking Water Watch

Inorganic Chemicals Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 07/29/2020 9.11 AM

Facility Source/Plant: TP001 WELL #2, 3 & 4 TREATMENT PLANT Lab Received: 07/29/2020

Sampling Pt: DEP001 Redacted

Address: 113 CHAMBER ST MILTON DE

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S925777 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

Field Results Free Chlorine: 0.410 Total Chlorine: 1.320

pH: 6.7 Temperature:

Flow Rate: Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1055	SULFATE	300.0	07/30/2020 10.26 AM 07/30/2020 10.26 AM	07/31/2020	
Detection: 11.7416 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1041	NITRITE	300.0	07/30/2020 10.26 AM 07/30/2020 10.26 AM	07/31/2020	
Detection: < 0.1 MG/L					

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 07/29/2020 9.11 AM
 Facility Source/Plant: TP001 WELL #2, 3 & 4 TREATMENT PLANT Lab Received: 07/29/2020
 Sampling Pt: DEP001 Redacted
 Address: 113 CHAMBER ST MILTON DE
 Sample Type: ROUTINE For Compliance: Yes
 Lab Sample No: S925777 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
 State Sample No:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1040	NITRATE	300.0	07/30/2020 10.26 AM 07/30/2020 10.26 AM	07/31/2020	
Detection: 4.9855 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1025	FLUORIDE	300.0	07/30/2020 10.26 AM 07/30/2020 10.26 AM	07/31/2020	
Detection: 0.1706 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1017	CHLORIDE	300.0	07/30/2020 10.26 AM 07/30/2020 10.26 AM	07/31/2020	
Detection: 24.5721 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1038	NITRATE-NITRITE				
Detection: 4.9855 MG/L					

Water System:	DE0000629	MILTON WATER DEPARTMENT	Sample Collected:	07/29/2020	9.11 AM
Facility Source/Plant:	TP001	WELL #2, 3 & 4 TREATMENT PLANT	Lab Received:	07/29/2020	
Sampling Pt:	DEP001	Redacted			
Address:	113 CHAMBER ST	MILTON DE			
Sample Type:	ROUTINE				
Lab Sample No:	S925777				
State Sample No:					
			For Compliance:	Yes	
			Laboratory:	DE017	DELAWARE PUBLIC HEALTH LABORATORY
