

DE0000629 MILTON WATER DEPARTMENT

Sample Collected: 06/29/2020

10.08 AM

Lab Received:

06/29/2020

Water System:

Facility Source/Plant: DS001 **DISTRIBUTION SYSTEM**

Sampling Pt: TCR_RT Redacted

Address: 210 FRONT ST MILTON DE 19968 US

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S925774 Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

PH 6.97

State Sample No:

Field Results Free Chlorine: 0.510 Total Chlorine:

Flow Rate: Turbidity:

Temperature:

0.940

3100 COLIFORM (TCR) RESULT Analyte 9223B-PA Method 06/30/2020 2.27 PM 06/30/2020 2.27 PM Analysis Start and End Dates 07/02/2020 State Notified On **PWS Notified On**

3014 E. COLI RESULT Analyte 9223B-PA Method **Analysis Start and End Dates** 06/30/2020 2.27 PM 06/30/2020 2.27 PM 07/02/2020 State Notified On **PWS Notified On**

Detection: Absent

Detection: Absent

February 01, 2021 \$925774 Page 1 of 2

Facility Source/Plant: DS001 DISTRIBUTION SYSTEM

Sampling Pt: TCR_RT Redacted
Address: 210 FRONT ST MILTON DE 19968 US

Sample Type: ROUTINE For Compliance: Yes

State Sample No:

Lab Sample No: S925774

Laboratory:

DE017

PH 6.97

Sample Collected: 06/29/2020

Lab Received: 06/29/2020

10.08 AM

DELAWARE PUBLIC HEALTH LABORATORY



Sample Collected: 06/29/2020

10.08 AM

Lab Received:

06/29/2020

Water System: DE0000629 MILTON WATER DEPARTMENT

Facility Source/Plant: DS001 **DISTRIBUTION SYSTEM**

Sampling Pt: TCR_RT Redacted

Address: 210 FRONT ST MILTON DE 19968 US

Lab Sample No: Sample Type: S925774 ROUTINE Laboratory: For Compliance: Yes

DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

PH 6.97

Field Results

Free Chlorine:

0.510

Ë

Flow Rate:

Total Chlorine: 0.940

Temperature:

Turbidity:

RESULT Analyte	Method	Analysis Start and End Dates	End Dates	State Notified On	PWS Notified On
3100 COLIFORM (TCR)	9223B-PA	06/30/2020 2.27 PM	PM 06/30/2020 2.27 PM	07/02/2020	
Detection: Absent					

יירטטרי אופיויים	pomen	Analysis Start and End Dates	ון שנוים בנוס ה	ales.	SIZIE NOUSEO OS	LAND MODILION OF
3014 E. COLI 922:	9223B-PA	06/30/2020 2.27 PM	2.27 PM	06/30/2020 2.27 PM	07/02/2020	

February 01, 2021 S925774 Page 1 of 2

Water System: DE0000629 MILTON WATER DEPARTMENT

Facility Source/Plant: DS001 DISTRIBUTION SYSTEM

Sampling Pt: TCR_RT Redacted

Address: 210 FRONT ST MILTON DE 19968 US

Sample Type: ROUTINE

Lab Sample No: S925774

Laboratory:

DE017

For Compliance: Yes

PH 6.97

State Sample No:

Sample Collected: 06/29/2020

10.08 AM

Lab Received:

06/29/2020

DELAWARE PUBLIC HEALTH LABORATORY



Water System: DE0000629 MILTON WATER DEPARTMENT

Facility Source/Plant: DS001 DISTRIBUTION SYSTEM

Lab Received:

06/29/2020

Sample Collected: 06/29/2020

9.04 AM

Sampling Pt: TCR_RT Redacted

Address: 113 CHANDLER ST MILTON DE 19968 OT

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S925801

DE017

DELAWARE PUBLIC HEALTH LABORATORY

PH 6.98

State Sample No:

Field Results Free Chlorine: 0.960 Total Chlorine:

멀

Flow Rate: Turbidity:

Temperature:

1.230

3100 COLIFORM (TCR) RESULT Analyte 9223B-PA Method 06/30/2020 2.27 PM 06/30/2020 2.27 PM **Analysis Start and End Dates** 07/02/2020 State Notified On PWS Notified On

Detection: Absent

3014 E. COLI RESULT Analyte Method 9223B-PA **Analysis Start and End Dates** 06/30/2020 2.27 PM 06/30/2020 2.27 PM 07/02/2020 State Notified On **PWS Notified On**

Detection: Absent

February 01, 2021

S925801

Water System: DE0000629 MILTON WATER DEPARTMENT **DISTRIBUTION SYSTEM** Sample Collected: 06/29/2020

Facility Source/Plant: DS001 TCR_RT

Sampling Pt: Address: 113 CHANDLER ST MILTON DE 19968 OT

Sample Type: ROUTINE

Lab Sample No: S925801

State Sample No:

PH 6.98

Redacted

For Compliance: Yes

Laboratory:

DE017

Lab Received: 06/29/2020

9.04 AM

DELAWARE PUBLIC HEALTH LABORATORY



Sample Collected: 06/29/2020

9.04 AM

Lab Received:

06/29/2020

Water System: DE0000629 MILTON WATER DEPARTMENT

Facility Source/Plant: DS001 **DISTRIBUTION SYSTEM**

Sampling Pt: TCR_RT Redacted

Address: 113 CHANDLER ST MILTON DE 19968 OT

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S925801

DELAWARE PUBLIC HEALTH LABORATORY

Laboratory: **DE017**

State Sample No:

Field Results Free Chlorine: 0.960

<u></u> 모:

Flow Rate:

Total Chlorine: 1.230

Temperature:

Turbidity:

3100 COLIFORM (TCR) Detection: Absent RESULT Analyte 9223B-PA Method 06/30/2020 2.27 PM 06/30/2020 2.27 PM Analysis Start and End Dates 07/02/2020 State Notified On **PWS Notified On**

RESULT Analyte 3014 E. COLI Method 9223B-PA 06/30/2020 2.27 PM **Analysis Start and End Dates** 06/30/2020 2.27 PM 07/02/2020 State Notified On **PWS Notified On**

Detection: Absent

9.04 AM

February 01, 2021

S925801

Page 2 of 2



Sample Collected: 06/29/2020

9.28 AM

Lab Received:

06/29/2020

Water System: DE0000629 MILTON WATER DEPARTMENT

Facility Source/Plant: DS001 DISTRIBUTION SYSTEM

Sampling Pt: TCR_RT Redacted

Address: 610 MULBERRY ST MILTON DE 19968 BS

Sample Type: ROUTINE For Compliance: Yes

Laboratory:

DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

Lab Sample No:

S925802

6.97 PH

Field Results Free Chlorine: 0.320 Total Chlorine: 0.470

Flow Rate:

Turbidity:

Temperature:

3100 COLIFORM (TCR) RESULT Analyte 9223B-PA Method 06/30/2020 2.27 PM Analysis Start and End Dates 06/30/2020 2.27 PM 07/02/2020 State Notified On **PWS Notified On**

Detection: Absent

3014 E. COLI RESULT Analyte Method 9223B-PA 06/30/2020 2.27 PM **Analysis Start and End Dates** 06/30/2020 2.27 PM 07/02/2020 State Notified On **PWS Notified On**

Detection: Absent

February 01, 2021 S925802

Page 1 of 2

6.97 PH



Sample Collected: 06/29/2020

9.28 AM

Lab Received:

06/29/2020

Water System: DE0000629 MILTON WATER DEPARTMENT

Facility Source/Plant: DS001 DISTRIBUTION SYSTEM

Sampling Pt: TCR_RT Redacted

Address: 610 MULBERRY ST MILTON DE 19968 BS

Sample Type: Lab Sample No: S925802 ROUTINE Laboratory: For Compliance: Yes

DE017

DELAWARE PUBLIC HEALTH LABORATORY

6.97 PH State Sample No:

Field Results Free Chlorine: 0.320 Total Chlorine: 0.470

Ä

Flow Rate:

Turbidity:

Temperature:

3100 COLIFORM (TCR) RESULT Analyte 9223B-PA Method 06/30/2020 2.27 PM **Analysis Start and End Dates** 06/30/2020 2.27 PM 07/02/2020 State Notified On PWS Notified On

Detection: Absent

RESULT Analyte	Method	Analysis Start and End Date	Dates	State Notified Ch	PARS Noulled Of
3014 E. COLI	9223B-PA	06/30/2020 2.27 PM	06/30/2020 2.27 PM	07/02/2020	

Detection: Absent

February 01, 2021

S925802

Page 1 of 2

Sampling Pt: Facility Source/Plant: DS001 TCR_RT Redacted **DISTRIBUTION SYSTEM**

Sample Type: Address: 610 MULBERRY ST MILTON DE 19968 BS ROUTINE

Lab Sample No: S925802

Laboratory:

DE017

For Compliance: Yes

6.97 PH State Sample No:

Sample Collected: 06/29/2020

9.28 AM

Lab Received: 06/29/2020

DELAWARE PUBLIC HEALTH LABORATORY



Sample Collected: 06/29/2020

9.43 AM

Lab Received:

06/29/2020

Water System: DE0000629 MILTON WATER DEPARTMENT

Facility Source/Plant: DS001 DISTRIBUTION SYSTEM

Sampling Pt: TCR_RT Redacted

Address: 701 FEDERAL ST MILTON DE 19968 KS

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S925803 Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

PH 6.97

State Sample No:

Field Results Free Chlorine: 0.350

와:

Flow Rate:

Total Chlorine: 0.500

Temperature:

Turbidity:

RESULT Analyte	Method	Analysis Start and End Dates		State Notified On	PWS Notified On
3100 COLIFORM (TCR)	9223B-PA	06/30/2020 2.27 PM 06/30/202	06/30/2020 2.27 PM	07/02/2020	
Detection: Absent					
RESULT Analyte	Method	Analysis Start and End Dates		State Notified On	PWS Notified On
3014 E. COLI	9223B-PA	06/30/2020 2.27 PM 06/30/202	06/30/2020 2.27 PM	07/02/2020	

February 01, 2021

S925803

Page 1 of 2

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT

Facility Source/Plant: DS001 DISTRIBUTION SYSTEM

Sampling Pt: TCR_RT

Address: 701 FEDERAL ST MILTON DE 19968 KS Redacted

Sample Type: ROUTINE

Lab Sample No: S925803

Laboratory:

DE017

For Compliance: Yes

State Sample No:

PH 6.97

Sample Collected: 06/29/2020

9.43 AM

Lab Received:

06/29/2020

DELAWARE PUBLIC HEALTH LABORATORY

S925803



Water System: DE0000629 MILTON WATER DEPARTMENT

Facility Source/Plant: DS001 DISTRIBUTION SYSTEM

Lab Received:

06/29/2020

Sample Collected: 06/29/2020

9.43 AM

Sampling Pt: TCR_RT Redacted

Address: 701 FEDERAL ST MILTON DE 19968 KS

Sample Type: Lab Sample No: S925803 ROUTINE Laboratory: For Compliance: Yes DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

PH 6.97

Free Chlorine: 0.350 Total Chlorine:

Field Results

Temperature:

0.500

Turbidity:

Flow Rate:

3100 COLIFORM (TCR) RESULT Analyte 9223B-PA Method 06/30/2020 2.27 PM **Analysis Start and End Dates** 06/30/2020 2.27 PM 07/02/2020 State Notified On **PWS Notified On**

Detection: Absent

3014 E. COLI RESULT Analyte 9223B-PA Method 06/30/2020 2.27 PM **Analysis Start and End Dates** 06/30/2020 2.27 PM 07/02/2020 State Notified On PWS Notified On

February 01, 2021

Detection: Absent

S925803

Page 1 of 2

Sample Type: Sampling Pt: Facility Source/Plant: DS001 Lab Sample No: S925803 Address: Water System: DE0000629 TCR_RT ROUTINE 701 FEDERAL ST MILTON DE 19968 KS MILTON WATER DEPARTMENT **DISTRIBUTION SYSTEM** Redacted Laboratory: For Compliance: Yes DE017 DELAWARE PUBLIC HEALTH LABORATORY Sample Collected: 06/29/2020 Lab Received: 06/29/2020

9.43 AM

State Sample No:

PH 6.97



Inorganic Chemicals Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT

Facility Source/Plant: TP001 WELL #2, 3 & 4 TREATMENT PLANT

Lab Received:

06/29/2020

Sample Collected: 06/29/2020

9.03 AM

Sampling Pt: DEP001 Redacted

Address: 113 CHANDLER ST MILTON DE 19968

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S925799 Laboratory: **DE017**

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

Field Results Free Chlorine: 0.960 Total Chlorine:

1.230

7.0 Temperature

P.

Flow Rate:

Turbidity:

Detection: 11.893 MG/L 1055 SULFATE RESULT Analyte 300.0 Method 06/30/2020 9.22 AM Analysis Start and End Dates 06/30/2020 9.22 AM 07/02/2020 State Notified On PWS Notified On

1041 NITRITE RESULT Analyte 300.0 Method **Analysis Start and End Dates** 06/30/2020 9.22 AM 06/30/2020 9.22 AM 07/02/2020 State Notified On **PWS Notified On**

Detection: < 0.1 MG/L

Page 1 of 3

Water System: Facility Source/Plant: TP001 DE0000629 WELL #2, 3 & 4 TREATMENT PLANT MILTON WATER DEPARTMENT Lab Received: Sample Collected: 06/29/2020

Sampling Pt: DEP001

Address: 113 CHANDLER ST MILTON DE 19968 Redacted

Sample Type: Lab Sample No: S925799

ROUTINE Laboratory: For Compliance: Yes DE017

DELAWARE PUBLIC HEALTH LABORATORY

06/29/2020

9.03 AM

State Sample No:

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1040 NITRATE	300.0	06/30/2020 9.22 AM 06/30/2020 9.22 AM	07/02/2020	
Detection: 4.9111 MG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1025 FLUORIDE	300.0	06/30/2020 9.22 AM 06/30/2020 9.22 AM	07/02/2020	
Detection: 0.1665 MG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1017 CHLORIDE	300.0	06/30/2020 9.22 AM 06/30/2020 9.22 AM	07/02/2020	
Detection: 23.7569 MG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1038 NITRATE-NITRITE				Philosophia and Philosophia and Philosophia

February 01, 2021

S925799

Page 2 of 3

Detection: 4.9111 MG/L

Laboratory:

DE017

DELAWARE PUBLIC HEALTH LABORATORY

Lab Received:

06/29/2020

Sample Collected: 06/29/2020

9.03 AM

For Compliance: Yes

February 01, 2021



rinking Water Watch

Synthetic Organic Chemicals Sample Report

Water System: DE0000629

Facility Source/Plant: TP001

Sampling Pt: MARINA FFT DEP001

Address:

Sample Type: ROUTINE

Lab Sample No: 4657792

MILTON WATER DEPARTMENT WELL #2, 3 & 4 TREATMENT PLANT

Lab Received:

06/25/2020

Sample Collected: 06/24/2020

8.05 AM

Redacted

For Compliance: Yes

Laboratory: E87775

EUROFINS

State Sample No: S952642 2051 LASSO RESULT Analyte 525.2 Method Analysis Start and End Dates State Notified On 07/20/2020 **PWS Notified On**

Detection: < 0.1 UG/L

2356 ALDRIN RESULT Analyte 525.2 Method **Analysis Start and End Dates** State Notified On 07/20/2020 **PWS Notified On**

Detection: < 0.1 UG/L

2050 ATRAZINE RESULT Analyte 525.2 Method Analysis Start and End Dates State Notified On 07/20/2020 **PWS Notified On**

Detection: < 0.1 UG/L

Facility Source/Plant: TP001 Water System: DE0000629 WELL #2, 3 & 4 TREATMENT PLANT MILTON WATER DEPARTMENT Sample Collected: 06/24/2020 Lab Received: 06/25/2020 8.05 AM

Sampling Pt: Sample Type: Address: DEP001 ROUTINE MARINA FFT Redacted For Compliance: Yes

State Sample No: S952642 Lab Sample No: 4657792 Laboratory: E87775

EUROFINS

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2306 BENZO(A)PYRENE	525.2		07/20/2020	
Detection: < 0.02 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2010 BHC-GAMMA	525.2		07/20/2020	
Detection: < 0.02 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2076 BUTACHLOR	525.2		07/20/2020	
Detection: < 0.1 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2070 DIELDRIN	525.2		07/20/2020	
Detection: < 0.1 UG/L				

Sample Type: Address: Sampling Pt: Facility Source/Plant: TP001 Water System: DE0000629 Lab Sample No: 4657792 ROUTINE MARINA FFT DEP001 Redacted WELL #2, 3 & 4 TREATMENT PLANT MILTON WATER DEPARTMENT For Compliance: Yes E87775 **EUROFINS** Lab Received: Sample Collected: 06/24/2020 06/25/2020 8.05 AM

Laboratory:

State Sample No: S952642

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2035 DI(2-ETHYLHEXYL) Detection: < 0.6 UG/L	525.2		07/20/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2039 DI(2-ETHYLHEXYL) Detection: < 0.6 UG/L	525.2		07/20/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2005 ENDRIN	525.2		07/20/2020	
Detection: < 0.01 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2065 HEPTACHLOR	525.2		07/20/2020	

February 01, 2021

4657792

Page 3 of 6

Detection: < 0.04 UG/L

Water System:DE0000629MILTON WATER DEPARTMENTSample Collected:06/24/2020Facility Source/Plant:TP001WELL #2, 3 & 4 TREATMENT PLANTLab Received:06/25/2020Sampling Pt:DEP001RedactedAddress:MARINA FFTSample Type:ROUTINEFor Compliance: YesLab Sample No:4657792Laboratory:E87775				S952642	State Sample No: S952642
DE0000629 MILTON WATER DEPARTMENT TP001 WELL #2, 3 & 4 TREATMENT PLANT Redacted RARINA FFT ROUTINE For Compliance: Yes		EUROFINS		4657792	Lab Sample No:
n: DE0000629 MILTON WATER DEPARTMENT Plant: TP001 WELL #2, 3 & 4 TREATMENT PLANT DEP001 Redacted MARINA FFT			For Compliance: Yes	ROUTINE	Sample Type:
n: DE0000629 MILTON WATER DEPARTMENT Plant: TP001 WELL #2, 3 & 4 TREATMENT PLANT DEP001 Redacted				MARINA FFT	Address:
0629 MILTON WATER DEPARTMENT WELL #2, 3 & 4 TREATMENT PLANT			Redacted	DEP001	Sampling Pt:
MILTON WATER DEPARTMENT	06/25	Lab Received:	WELL #2, 3 & 4 TREATMENT PLANT	TP001	Facility Source/Plant:
	06/2	Sample Collected:	MILTON WATER DEPARTMENT	DE0000629	Water System:

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2067 HEPTACHLOR	525.2		07/20/2020	
Detection: < 0.02 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2274 HEXACHLOROBENZ	525.2		07/20/2020	
Detection: < 0.1 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2042 HEXACHLOROCYCL	525.2		07/20/2020	
Detection: < 0.1 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2015 METHOXYCHLOR	525.2		07/20/2020	
Detection: < 0.1 UG/L				

February 01, 2021

4657792

Page 4 of 6

Address: N	Sampling Pt: [Facility Source/Plant: TP001	Water System: [
MARINA FFT	DEP001	ГР001	DE0000629
	Redacted	WELL #2, 3 & 4 TREATMENT PLANT	MILTON WATER DEPARTMENT
		Lab Received:	Sample Collected: 06/24/2020
		06/25/2020	06/24/2020
			8.05 AM

State Sample No: S952642

Lab Sample No: 4657792

For Compliance: Yes
Laboratory: E87775

EUROFINS

Sample Type:

ROUTINE

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2045 METOLACHLOR	525.2		07/20/2020	
Detection: < 0.1 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2595 METRIBUZIN	525.2		07/20/2020	
Detection: < 0.1 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notffled On	PWS Notified On
2077 PROPACHLOR	525.2		07/20/2020	
Detection: < 0.1 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2037 SIMAZINE	525.2		07/20/2020	
Detection: < 0.07 UG/L				

February 01, 2021

4657792

Page 5 of 6

Water System: DE0000629

Sampling Pt: Facility Source/Plant: TP001

DEP001

Address: ROUTINE MARINA FFT

Sample Type:

Lab Sample No: 4657792

State Sample No: S952642

MILTON WATER DEPARTMENT

WELL #2, 3 & 4 TREATMENT PLANT

Lab Received:

06/25/2020

Sample Collected: 06/24/2020

8.05 AM

Redacted

E87775

Laboratory:

For Compliance: Yes

EUROFINS



rinking Water

Synthetic Organic Chemicals Sample Report

Water System: DE0000629

Facility Source/Plant: TP001
Sampling Pt: DEP001

Address: MARINA FFT Sample Type: ROUTINE

Lab Sample No: 4657793

State Sample No: S952643

RESULT Analyte 2105 2,4-D

515.3

Method

Detection: < 0.1 UG/L

MILTON WATER DEPARTMENT
WELL #2, 3 & 4 TREATMENT PLANT

Lab Received:

06/25/2020

Sample Collected: 06/24/2020

8.05 AM

Redacted

For Compliance: Yes

Laboratory: E87775

EUROFINS

Analysis Start and End Dates

07/20/2020

State Notified On

PWS Notified On

RESULT Analyte 2031 DALAPON 515.3 Method **Analysis Start and End Dates** 07/20/2020 State Notified On **PWS Notified On**

Detection: < 1 UG/L

Detection: < 0.1 UG/L

RESULT Analyte
2440 DICAMBA

515.3

Method

Analysis Start and End Dates

07/20/2020

State Notified On

PWS Notified On

Facility Source/Plant: TP001 Water System: DE0000629 DEP001 WELL #2, 3 & 4 TREATMENT PLANT MILTON WATER DEPARTMENT Redacted Lab Received: Sample Collected: 06/24/2020 06/25/2020 8.05 AM

Sampling Pt: DEP001

Address: MARINA FFT

Sample Type: ROUTINE

Sample Type: ROUTINE
Lab Sample No: 4657793
State Sample No: S952643

For Compliance: Yes

Laboratory: E87775

EUROFINS

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2041 DINOSEB Detection: < 0.1 UG/L	515.3		07/20/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2326 PENTACHLOROPHE	515.3		07/20/2020	
Detection: < 0.04 UG/L			•	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2040 PICLORAM	515.3		07/20/2020	
Detection: < 0.1 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2110 2,4,5-TP	515.3		07/20/2020	
Detection: < 0.1 UG/L				

February 01, 2021

4657793

Page 2 of 3

4657793

Sample Collected: 06/24/2020 8.05 AM

Water System: DE0000629

Sampling Pt: Facility Source/Plant: TP001 DEP001

Sample Type: Address: MARINA FFT

ROUTINE

State Sample No: S952643 Lab Sample No: 4657793

MILTON WATER DEPARTMENT

WELL #2, 3 & 4 TREATMENT PLANT

Redacted

For Compliance: Yes

Laboratory: E87775

Lab Received:

06/25/2020

EUROFINS

Page 3 of 3



Synthetic Organic Chemicals Sample Report

Water System: DE0000629

Facility Source/Plant: TP001

Sampling Pt: DEP001 MARINA FFT

Address:

Sample Type: ROUTINE

Lab Sample No: 4657794

MILTON WATER DEPARTMENT

Sample Collected: 06/24/2020

8.05 AM

Lab Received:

06/25/2020

WELL #2, 3 & 4 TREATMENT PLANT

Redacted

For Compliance: Yes

Laboratory: E87775

EUROFINS

State Sample No: S952644 2388 AROCLOR 1016 RESULT Analyte Method Analysis Start and End Dates 07/20/2020 State Notified On **PWS Notified On**

Detection: < 0.08 UG/L

Analysis Start and End Dates 07/20/2020

State Notified On

PWS Notified On

2390 AROCLOR 1221

RESULT Analyte

Method

Detection: < 0.19 UG/L

2392 AROCLOR 1232

Detection:

< 0.23 UG/L

RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

07/20/2020

4657794

Page 1 of 3

February 01, 2021

Facility Source/Plant: TP001 Water System: DE0000629 WELL #2, 3 & 4 TREATMENT PLANT MILTON WATER DEPARTMENT Sample Collected: 06/24/2020 Lab Received: 06/25/2020 8.05 AM

Sample Type: Sampling Pt: Address: DEP001 ROUTINE MARINA FFT Redacted For Compliance: Yes

State Sample No: S952644 Lab Sample No: 4657794 Laboratory: E87775 **EUROFINS**

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2394 AROCLOR 1242			07/20/2020	
Detection: < 0.26 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2396 AROCLOR 1248			07/20/2020	
Detection: < 0.1 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2398 AROCLOR 1254			07/20/2020	
Detection: < 0.1 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2400 AROCLOR 1260			07/20/2020	
Detection: < 0.2 UG/L				

February 01, 2021

4657794

Page 2 of 3

8.05 AM

Laboratory: For Compliance: Yes E87775 **EUROFINS**

State Sample No: S952644

Lab Sample No: 4657794

Sample Type:

ROUTINE

Address:

Detection: < 1 UG/L 2020 TOXAPHENE RESULT Analyte 2959 CHLORDANE RESULT Analyte Detection: < 0.1 UG/L **505** 505 Method Method **Analysis Start and End Dates Analysis Start and End Dates** 07/20/2020 State Notified On 07/20/2020 State Notified On **PWS Notified On PWS Notified On**



Synthetic Organic Chemicals Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT

Facility Source/Plant: TP001 WELL #2, 3 & 4 TREATMENT PLANT

Lab Received:

06/25/2020

Sample Collected: 06/24/2020

8.05 AM

Redacted

Sampling Pt:

DEP001

For Compliance: Yes

Laboratory: E87775

State Sample No: S952645

Sample Type:

ROUTINE

MARINA FFT

Lab Sample No: 4657795

Address:

EUROFINS

Analysis Start and End Dates 07/20/2020

State Notified On

PWS Notified On

Detection: < 0.01 UG/L

2931 1,2-DIBROMO-3-

504.1

Method

RESULT Analyte

2946 ETHYLENE RESULT Analyte 504.1 Method Analysis Start and End Dates 07/20/2020 State Notified On PWS Notified On

Detection: < 0.01 UG/L



rinking Water Watch

Synthetic Organic Chemicals Sample Report

Water System: DE0000629

Facility Source/Plant: TP001

Address: Sampling Pt: DEP001 MARINA FFT

Sample Type: ROUTINE

State Sample No: S952647 Lab Sample No: 4657797

MILTON WATER DEPARTMENT

Sample Collected: 06/24/2020

8.05 AM

Lab Received:

06/25/2020

WELL #2, 3 & 4 TREATMENT PLANT

Redacted

For Compliance: Yes

Laboratory: E87775

EUROFINS

2047 ALDICARB RESULT Analyte RESULT Analyte Detection: < 0.5 UG/L Method Method **Analysis Start and End Dates** Analysis Start and End Dates State Notified On State Notified On 07/20/2020 PWS Notified On **PWS Notified On**

Detection: < 0.7 UG/L

2044 ALDICARB

2043 ALDICARB RESULT Analyte

Method

Analysis Start and End Dates

07/20/2020

State Notified On

PWS Notified On

07/20/2020

Detection: < 0.5 UG/L

Facility Source/Plant: TP001 Water System: DE0000629 DEP001 WELL #2, 3 & 4 TREATMENT PLANT MILTON WATER DEPARTMENT Lab Received: Sample Collected: 06/24/2020 06/25/2020 8.05 AM

Sample Type: Address: Lab Sample No: 4657797 ROUTINE MARINA FFT Laboratory: For Compliance: Yes

Sampling Pt:

Redacted

State Sample No: S952647 E87775

EUROFINS

			The state of the s	
2021 CARBARYL			07/20/2020	
Detection: < 0.5 UG/L				
The contract of the contract o				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2046 CARBOFURAN			07/20/2020	
Detection: < 0.9 UG/L				
		Analysis State and End Dates	State Nottled On	DWG Notified On
2088 3			02/20/2020	

2022 METHOMYL RESULT Analyte

Method

Analysis Start and End Dates

07/20/2020

State Notified On

PWS Notified On

Detection: < 0.5 UG/L

Detection: < 0.5 UG/L

Laboratory: E87775 EUROFINS

For Compliance: Yes

State Sample No: S952647

Lab Sample No: 4657797

Sample Type:

ROUTINE

2036 OXAMYL RESULT Analyte 2259 1-NAPHTHOL RESULT Analyte Detection: < 1 UG/L Detection: < 1 UG/L Method Method Analysis Start and End Dates Analysis Start and End Dates 07/20/2020 State Notified On 07/20/2020 State Notified On **PWS Notified On PWS Notified On**



Sample Report

Sample Collected: 06/15/2020

8.30 AM

Lab Received:

06/15/2020

Water System: DE0000629 MILTON WATER DEPARTMENT

Facility Source/Plant: DS001 DISTRIBUTION SYSTEM

Sampling Pt: **DBPS201** Redacted

Address: MARINER SCHOOL MENS ROOM MBS

Sample Type: ROUTINE

Lab Sample No: S952654 Laboratory: For Compliance: Yes DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

Field Results Free Chlorine: 0.400 Total Chlorine:

Flow Rate:

Turbidity:

Temperature:

2998 N-PROPYLBENZENE RESULT Analyte 524.2 Method 06/18/2020 4.54 PM 06/24/2020 2.48 PM **Analysis Start and End Dates** 06/25/2020 State Notified On PWS Notified On

Detection: < 0.5 UG/L

							Salary was 53
ed Cn PWS Notified	State Notified Or	Dates	alysis Start and End Dat	Analysis Sta	Method	ESULT Analyte	RESUL

Detection: < 0.5 UG/L

Facility Source/Plant: DS001 Water System: DE0000629 MILTON WATER DEPARTMENT **DISTRIBUTION SYSTEM**

Lab Received:

06/15/2020

Sample Collected: 06/15/2020

8.30 AM

Sampling Pt: **DBPS201** Redacted

MARINER SCHOOL MENS ROOM MBS

Sample Type: Address: ROUTINE For Compliance: Yes

Lab Sample No: S952654

State Sample No: Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2994 ISOPROPYLBENZEN Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2993 BROMOBENZENE Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2992 ETHYLBENZENE Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2991 TOLUENE Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	

February 01, 2021

S952654

Page 2 of 16

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 06/15/2020

Facility Source/Plant: DS001 **DISTRIBUTION SYSTEM**

Sampling Pt: Address: **DBPS201** MARINER SCHOOL MENS ROOM MBS Redacted

Sample Type: Lab Sample No: \$952654 ROUTINE

State Sample No:

Laboratory: For Compliance: Yes DE017

8.30 AM

Lab Received: 06/15/2020

RECIT Analyta	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2990 BENZENE	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2989 CHLOROBENZENE	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2988 1,1,2,2-	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2987 TETRACHLOROETH	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L				

Sampling Pt: Facility Source/Plant: DS001 Address: Water System: DE0000629 MARINER SCHOOL MENS ROOM MBS **DBPS201 DISTRIBUTION SYSTEM** MILTON WATER DEPARTMENT Redacted Lab Received: Sample Collected: 06/15/2020 06/15/2020 8.30 AM

2986 1,1,1,2-RESULT Analyte 524.2 Method 06/18/2020 4.54 PM 06/24/2020 2.48 PM **Analysis Start and End Dates** 06/25/2020 State Notified On **PWS Notified On** State Sample No:

Detection:

< 0.5 UG/L

Lab Sample No:

S952654

Laboratory:

DE017

DELAWARE PUBLIC HEALTH LABORATORY

For Compliance: Yes

Sample Type:

ROUTINE

Detection: < 0.5 UG/L 2985 1,1,2-RESULT Analyte 524.2 Method 06/18/2020 4.54 PM 06/24/2020 2.48 PM **Analysis Start and End Dates** 06/25/2020 State Notified On **PWS Notified On**

Detection: < 0.5 UG/L 2984 TRICHLOROETHYLE RESULT Analyte 524.2 Method 06/18/2020 4.54 PM 06/24/2020 2.48 PM **Analysis Start and End Dates** 06/25/2020 State Notified On **PWS Notified On**

2983 1,2-RESULT Analyte 524.2 Method 06/18/2020 4.54 PM **Analysis Start and End Dates** 06/24/2020 2.48 PM 06/25/2020 State Notified On **PWS Notified On**

Detection: < 0.5 UG/L

Water System: DE0000629 DISTRIBUTION SYSTEM MILTON WATER DEPARTMENT Sample Collected: 06/15/2020 8.30 AM

Sampling Pt: Facility Source/Plant: DS001 **DBPS201** Redacted

Address: MARINER SCHOOL MENS ROOM MBS

Sample Type: Lab Sample No: S952654 ROUTINE Laboratory: For Compliance: Yes

State Sample No:

Lab Received: 06/15/2020

DELAWARE PUBLIC HEALTH LABORATORY

DE017

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2982 CARBON Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2981 1,1,1-	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2980 1,2-	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2979 TRANS-1,2-	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L				

February 01, 2021

S952654

Page 5 of 16

Facility Source/Plant: DS001 Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 06/15/2020 06/15/2020 8.30 AM

Sampling Pt: Address:

Sample Type: ROUTINE

State Sample No:

Lab Sample No: S952654 MARINER SCHOOL MENS ROOM MBS **DBPS201 DISTRIBUTION SYSTEM** Redacted Laboratory: For Compliance: Yes DE017 DELAWARE PUBLIC HEALTH LABORATORY Lab Received:

RESULT Analyte	Method	Analysis Start and End Dates	Dates	State Notified On	PWS Notified On
2978 1,1- Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM	06/24/2020 2.48 PM	06/25/2020	
RESULT Analyte	Method	Analysis Start and End Dates	Dates	State Notified On	PWS Notified On
2977 1,1-	524.2	06/18/2020 4.54 PM	06/24/2020 2.48 PM	06/25/2020	

RESULT Analyte	Method	Analysis Start and End Dates	Dates	State Notified On	PWS Notified On
2969 P-	524.2	06/18/2020 4.54 PM	06/24/2020 2.48 PM	06/25/2020	

2976 VINYL CHLORIDE

524.2 Method

Analysis Start and End Dates

06/18/2020 4.54 PM 06/24/2020 2.48 PM

06/25/2020

State Notified On

PWS Notified On

RESULT Analyte

Detection:

< 0.5 UG/L

Water System: DE0000629 MILTON WATER DEPARTMENT

Facility Source/Plant: DS001 DISTRIBUTION SYSTEM

Sampling Pt: DBPS201

Address: MARINER SCHOOL MENS ROOM MBS Redacted

Sample Type: Lab Sample No: S952654 ROUTINE For Compliance: Yes

Laboratory:

DE017

State Sample No:

Sample Collected: 06/15/2020

8.30 AM

Lab Received: 06/15/2020

RESULT Analyte	Method	Analysis Start and End Dates)ates	State Notified On	PWS Notified On
2968 O-	524.2	06/18/2020 4.54 PM	06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L					
RESULT Analyte	Method	Analysis Start and End Dates	Sates	State Notified On	PWS Notified On
2967 M-	524.2	06/18/2020 4.54 PM	06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L					
RESULT Analyte	Method	Analysis Start and End Dates	Dates	State Notified On	PWS Notified On
2966 P-	524.2	06/18/2020 4.54 PM	06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L					
RESULT Analyte	Method	Analysis Start and End Dates)ates	State Notified On	PWS Notified On
2965 O-	524.2	06/18/2020 4.54 PM	06/24/2020 2.48 PM	06/25/2020	

Facility Source/Plant: DS001 Water System: DE0000629 DISTRIBUTION SYSTEM MILTON WATER DEPARTMENT

Sampling Pt: **DBPS201** Redacted

Sample Type: Address: MARINER SCHOOL MENS ROOM MBS ROUTINE

Lab Sample No: S952654 Laboratory: For Compliance: Yes

State Sample No:

Sample Collected: 06/15/2020

8.30 AM

Lab Received: 06/15/2020

DELAWARE PUBLIC HEALTH LABORATORY

DE017

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2964 DICHLOROMETHAN Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2955 XYLENES, TOTAL Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2946 ETHYLENE Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2944 DIBROMOCHLOROM Detection: 1.46 UG/L	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	

Facility Source/Plant: DS001 Water System: DE0000629 **DISTRIBUTION SYSTEM** MILTON WATER DEPARTMENT Sample Collected: 06/15/2020 Lab Received: 06/15/2020 8.30 AM

Sampling Pt: **DBPS201** Redacted

Address: MARINER SCHOOL MENS ROOM MBS

Sample Type: Lab Sample No: S952654 ROUTINE Laboratory: For Compliance: Yes

State Sample No:

DE017

DELAWARE PUBLIC HEALTH LABORATORY

Analysis Start and End Dates

06/18/2020 4.54 PM 06/24/2020 2.48 PM

06/25/2020

State Notified On

PWS Notified On

Detection: 2.14 UG/L

2943 BROMODICHLOROM

524.2 Method

RESULT Analyte

RESULT Analyte	Method	Analysis Start and End Dates	Dates	State Notified On	PWS Notified On
2942 BROMOFORM	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PN	06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L					

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified Or
2941 CHLOROFORM	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	

Detection: 3.42 UG/L

RESULT Analyte Method	Analysis Start and End Dates	State Notified On	On PWS Notified On
POOL AS PIPPONS	06/18/2020 4.54 PM 06/24/2	06/24/2020 2.48 PM 06/25/2020	

Detection: < 0.5 UG/L

Facility Source/Plant: DS001 Water System: DE0000629 DISTRIBUTION SYSTEM MILTON WATER DEPARTMENT

Sampling Pt: **DBPS201** Redacted

Sample Type: Address: ROUTINE MARINER SCHOOL MENS ROOM MBS

State Sample No: Lab Sample No: S952654

Laboratory:

DE017

For Compliance: Yes

Lab Received:

Sample Collected: 06/15/2020

8.30 AM

06/15/2020

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2430 BROMOCHLOROME Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2428 SEC-	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2426 TERT- Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2424 1,3,5- Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	

Sample Type: Sampling Pt: Address: Facility Source/Plant: DS001 Water System: Lab Sample No: S952654 DE0000629 **DBPS201** ROUTINE MARINER SCHOOL MENS ROOM MBS **DISTRIBUTION SYSTEM** Redacted MILTON WATER DEPARTMENT Laboratory: For Compliance: Yes DE017 DELAWARE PUBLIC HEALTH LABORATORY Lab Received: Sample Collected: 06/15/2020 06/15/2020 8.30 AM

State Sample No:

RESULT Analyte 2422 N-BUTYLBENZENE	Method 524.2	Analysis Start and End Dates 06/18/2020 4.54 PM 06/24/2020 2.48 PM	State Notified On 06/25/2020	PWS Notified On
Detection: < 0.5 UG/L	524.2		05/20/2000	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2420 1,2,3- Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2418 1,2,4- Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	

2416 2,2-

Method 524.2

06/18/2020 4.54 PM 06/24/2020 2.48 PM

06/25/2020

State Notified On

PWS Notified On

Analysis Start and End Dates

Detection: < 0.5 UG/L

RESULT Analyte

Water System: DE0000629

Facility Source/Plant: DS001

DBPS201

Sampling Pt:

Address:

Sample Type: Lab Sample No: ROUTINE

S952654

State Sample No:

MILTON WATER DEPARTMENT

Sample Collected: 06/15/2020

8.30 AM

Lab Received:

06/15/2020

DISTRIBUTION SYSTEM

Redacted

MARINER SCHOOL MENS ROOM MBS

Laboratory: For Compliance: Yes DE017

DELAWARE PUBLIC HEALTH LABORATORY

2408 DIBROMOMETHANE RESULT Analyte 2410 1,1-RESULT Analyte 2412 1,3-RESULT Analyte 2414 1,2,3-Detection: Detection: < 0.5 UG/L Detection: < 0.5 UG/L RESULT Analyte Detection: < 0.5 UG/L < 0.5 UG/L 524.2 524.2 524.2 524.2 Method Method Method Method **Analysis Start and End Dates Analysis Start and End Dates** 06/18/2020 4.54 PM 06/18/2020 4.54 PM 06/24/2020 2.48 PM 06/18/2020 4.54 PM 06/24/2020 2.48 PM **Analysis Start and End Dates Analysis Start and End Dates** 06/18/2020 4.54 PM 06/24/2020 2.48 PM 06/24/2020 2.48 PM 06/25/2020 State Notified On 06/25/2020 06/25/2020 State Notified On State Notified On 06/25/2020 State Notified On **PWS Notified On PWS Notified On** PWS Notified On **PWS Notified On**

Water System: DE0000629 MILTON WATER DEPARTMENT

Facility Source/Plant: DS001

Sampling Pt: **DBPS201**

Address: ROUTINE

Sample Type: Lab Sample No: S952654

State Sample No:

DISTRIBUTION SYSTEM

MARINER SCHOOL MENS ROOM MBS Redacted

For Compliance: Yes

Laboratory: **DE017**

Sample Collected: 06/15/2020

8.30 AM

Lab Received: 06/15/2020

DELAWARE PUBLIC HEALTH LABORATORY

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2380 CIS-1,2-	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
1000				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2378 1,2,4-	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2251 METHYL TERT-	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2248 NAPHTHALENE	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L				

February 01, 2021

S952654

Page 13 of 16

Facility Source/Plant: DS001 Water System: DE0000629 MILTON WATER DEPARTMENT DISTRIBUTION SYSTEM

Sample Collected: 06/15/2020

8.30 AM

Lab Received:

06/15/2020

Sampling Pt: **DBPS201** Redacted

Address: MARINER SCHOOL MENS ROOM MBS

Sample Type: ROUTINE For Compliance: Yes

State Sample No: Lab Sample No: \$952654 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

RESULT Analyte	Method	Analysis Start and End Dates	Dates	State Notified On	PWS Notified On
2246 HEXACHLOROBUTA	524.2	06/18/2020 4.54 PM	06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L					
RESULT Analyte	Method	Analysis Start and End Dates	Dates	State Notified On	PWS Notified On
2228 CIS-1,3-	524.2	06/18/2020 4.54 PM	06/24/2020 2.48 PM	06/25/2020	The state of the s
Detection: < 0.5 UG/L					
RESULT Analyte	Method	Analysis Start and End Dates	Dates	State Notified On	PWS Notified On
2224 TRANS-1,3-	524.2	06/18/2020 4.54 PM	06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L					
RESULT Analyte	Method	Analysis Start and End Dates	Dates	State Notified On	PWS Notified On
2218 TRICHLOROFLUOR	524.2	06/18/2020 4.54 PM	06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L					

Facility Source/Plant: DS001 Water System: DE0000629 **DISTRIBUTION SYSTEM** MILTON WATER DEPARTMENT Lab Received: Sample Collected: 06/15/2020

06/15/2020

8.30 AM

Sampling Pt: DBPS201 Redacted

Address: MARINER SCHOOL MENS ROOM MBS

Sample Type: Lab Sample No: S952654 ROUTINE For Compliance: Yes

State Sample No:

Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2216 CHLOROETHANE Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2214 BROMOMETHANE Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2212 DICHLORODIFLUOR Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2210 CHLOROMETHANE	524.2	06/18/2020 4.54 PM 06/24/2020 2.48 PM	06/25/2020	
Detection: < 0.5 UG/L				

February 01, 2021

S952654

Page 15 of 16

Facility Source/Plant: DS001 Water System: DE0000629 **DISTRIBUTION SYSTEM** MILTON WATER DEPARTMENT

Sampling Pt: Address: **DBPS201**

MARINER SCHOOL MENS ROOM MBS Redacted

Sample Type: Lab Sample No: S952654 ROUTINE

State Sample No:

For Compliance: Yes

Laboratory: DE017

Sample Collected: 06/15/2020

8.30 AM

Lab Received: 06/15/2020

RESULT Analyte	Method	Analysis Start and End Dates	Dates	State Notified On	PWS Notified On
2030 P- Detection: < 0.5 UG/L	524.2	06/18/2020 4.54 PM	06/24/2020 2.48 PM	06/25/2020	
RESULT Analyte	Method	Analysis Start and End Dates	Dates	State Notified On	PWS Notified On
2950 TTHM Detection: 7.02 UG/L					



Disinfection By-Products Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT

Sample Collected: 06/15/2020

8.30 AM

Lab Received:

06/15/2020

Facility Source/Plant: DS001 **DISTRIBUTION SYSTEM**

Sampling Pt: **DBPS201** Redacted

Address: MARINER SCHOOL MENS ROOM MBS

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S952724

> Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

Field Results Free Chlorine: 0.400

Flow Rate:

Turbidity:

PWS Notified On

Temperature:

Total Chlorine:

2456 TOTAL HALOACETIC 552.2 Method **Analysis Start and End Dates** 06/25/2020 3.23 PM 06/25/2020 3.45 PM 07/02/2020 State Notified On

Detection: < 5 UG/L

RESULT Analyte

2454 DIBROMOACETIC RESULT Analyte 552.2 Method **Analysis Start and End Dates** 06/25/2020 3.23 PM 06/25/2020 3.45 PM 07/02/2020 State Notified On PWS Notified On

Detection: < 1 UG/L

Facility Source/Plant: DS001 Water System: DE0000629 DISTRIBUTION SYSTEM MILTON WATER DEPARTMENT Lab Received: Sample Collected: 06/15/2020 06/15/2020 8.30 AM

Sampling Pt: **DBPS201** Redacted

Address: MARINER SCHOOL MENS ROOM MBS

Sample Type: Lab Sample No: S952724 ROUTINE Laboratory: For Compliance: Yes

State

Sample No:	S952724	Laboratory:	DE017	DELAWARE PUBLIC HEALTH LABORATORY
te Sample No:				

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2453 MONOBROMOACETI	552.2	06/25/2020 3.23 PM 06/25/2020 3.45 PM	07/02/2020	
Detection: < 1 UG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2452 TRICHLOROACETIC	カカンン	08/25/2020 3 23 PM 08/25/2020 3 45 PM	07/02/2020	

RESULT Analyte	Method	Analysis Start and End Dates	irt and End I	ates	State Notified On	PWS Notified On
2451 DICHLOROACETIC	552.2	06/25/2020 3.23 PM	3.23 PM	06/25/2020 3.45	PM 07/02/2020	

Detection: < 1 UG/L

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2450 MONOCHLOROACE	552.2	06/25/2020 3.23 PM 06/25/2020 3.45 PM	07/02/2020	

Detection: < 1 UG/L

8.30 AM

Water System: DE0000629 MILTON WATER DEPARTMENT

Facility Source/Plant: DS001

DBPS201

Address: Sampling Pt: MARINER SCHOOL MENS ROOM MBS

Sample Type: Lab Sample No: S952724

State Sample No:

ROUTINE

DISTRIBUTION SYSTEM

Redacted

For Compliance: Yes

Laboratory:

DE017

Sample Collected: 06/15/2020

Lab Received: 06/15/2020



Radionuclides Sample Report

Sample Collected: 06/12/2020

8.40 AM

Lab Received:

06/12/2020

Water System: DE0000629 MILTON WATER DEPARTMENT

Facility Source/Plant: TP001 WELL #2, 3 & 4 TREATMENT PLANT

Sampling Pt: DEP001 Redacted

MILTON MEMORIAL PARK DOCKS FFT

Address:

Sample Type: Lab Sample No: S952771 ROUTINE Laboratory: For Compliance: Yes DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

Field Results

PH:

Flow Rate:

Free Chlorine: 0.380 Total Chlorine:

Temperature:

Turbidity:

4009 URANIUM-238 RESULT Analyte 200.8 Method **Analysis Start and End Dates** 06/12/2020 12:20 PM 06/16/2020 2:31 PM 06/20/2020 State Notified On PWS Notified On

Detection: < 0.0005 MG/L

	06/20/2020	06/16/2020 2.31 PM	12.20 PM	06/12/2020	200.8	1095 ZINC
PWS Notified On	State Notified On	ates	is Start and End Dates	Analysis Sta	Method	SULT Analyte

Detection: 0.05223 MG/L

Water System: DE0000629 MILTON WATER DEPARTMENT

Facility Source/Plant: TP001 WELL #2, 3 & 4 TREATMENT PLANT

Lab Received:

06/12/2020

Sample Collected: 06/12/2020

8.40 AM

Sampling Pt: Sample Type: Address: ROUTINE

MILTON MEMORIAL PARK DOCKS FFT DEP001 Redacted

Lab Sample No: S952771

State Sample No:

For Compliance: Yes

Laboratory:

DE017

DELAWARE PUBLIC HEALTH LABORATORY

1088 VANADIUM, TOTAL RESULT Analyte Detection: < 0.01 MG/L 200.8 Method 06/12/2020 12.20 PM 06/16/2020 2.31 PM **Analysis Start and End Dates** 06/20/2020 State Notified On **PWS Notified On**

RESULT Analyte Detection: 1085 THALLIUM, TOTAL < 0.0005 MG/L 200.8 Method 06/12/2020 12.20 PM 06/16/2020 2.31 PM **Analysis Start and End Dates** 06/20/2020 State Notified On **PWS Notified On**

RESULT Analyte Detection: 1075 BERYLLIUM, TOTAL < 0.0005 MG/L 200.8 Method 06/12/2020 12.20 PM 06/16/2020 2.31 PM **Analysis Start and End Dates** 06/20/2020 State Notified On **PWS Notified On**

1074 ANTIMONY, TOTAL RESULT Analyte 200.8 Method 06/12/2020 12.20 PM 06/16/2020 2.31 PM **Analysis Start and End Dates** 06/20/2020 State Notified On **PWS Notified On**

Detection: < 0.0005 MG/L

Address: Sampling Pt: Facility Source/Plant: TP001 Water System: DE0000629 MILTON MEMORIAL PARK DOCKS FFT **DEP001** WELL #2, 3 & 4 TREATMENT PLANT MILTON WATER DEPARTMENT Redacted Sample Collected: 06/12/2020 Lab Received: 06/12/2020 8.40 AM

Detection: 0.00098 MG/L 1045 SELENIUM RESULT Analyte 200.8 Method 06/12/2020 12.20 PM 06/16/2020 2.31 PM **Analysis Start and End Dates** 06/20/2020 State Notified On **PWS Notified On** State Sample No:

Sample Type: Lab Sample No:

ROUTINE

S952771

Laboratory:

DE017

DELAWARE PUBLIC HEALTH LABORATORY

For Compliance: Yes

Detection: < 0.01 MG/L RESULT Analyte 1036 NICKEL 200.8 Method 06/12/2020 12.20 PM 06/16/2020 2.31 PM Analysis Start and End Dates 06/20/2020 State Notified On **PWS Notified On**

Detection: < 0.0005 MG/L RESULT Analyte 1035 MERCURY 245.1 Method 06/15/2020 3.20 PM **Analysis Start and End Dates** 06/15/2020 3.20 PM 06/20/2020 State Notified On **PWS Notified On**

1032 MANGANESE RESULT Analyte 200.8 Method 06/12/2020 12.20 PM 06/16/2020 2.31 PM **Analysis Start and End Dates** 06/20/2020 State Notified On **PWS Notified On**

Detection: 0.01234 MG/L

Sampling Pt: Facility Source/Plant: TP001 Address: Water System: DEP001 DE0000629 MILTON MEMORIAL PARK DOCKS FFT WELL #2, 3 & 4 TREATMENT PLANT MILTON WATER DEPARTMENT Redacted Sample Collected: 06/12/2020 Lab Received: 06/12/2020 8.40 AM

State Sample No: Lab Sample No: S952771 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

For Compliance: Yes

Sample Type:

ROUTINE

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1030 LEAD Detection: 0.00050 MG/L	200.8	06/12/2020 12.20 PM 06/16/2020 2.31 PM	06/20/2020	
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1022 COPPER, FREE	200.8	06/12/2020 12.20 PM 06/16/2020 2.31 PM	06/20/2020	
Detection: 0.01904 MG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1020 CHROMIUM	200.8	06/12/2020 12.20 PM 06/16/2020 2.31 PM	06/20/2020	
Detection: < 0.01 MG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1015 CADMIUM	200.8	06/12/2020 12.20 PM 06/16/2020 2.31 PM	06/20/2020	
Detection: < 0.0005 MG/L				

February 01, 2021

S952771

Page 4 of 5

Facility Source/Plant: TP001 WELL #2, 3 & 4 TREATMENT PLANT

Sampling Pt: DEP001 Redacted

Address: MILTON MEMORIAL PARK DOCKS FFT

Sample Type: Lab Sample No: S952771 ROUTINE

State Sample No:

Laboratory: For Compliance: Yes DE017

Sample Collected: 06/12/2020

8.40 AM

Lab Received: 06/12/2020

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1010 BARIUM	200.8	06/12/2020 12.20 PM 06/16/2020 2.31 PM	06/20/2020	
Detection: 0.11352 MG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1005 ARSENIC	200.8	06/12/2020 12.20 PM 06/16/2020 2.31 PM	06/20/2020	
Detection: < 0.0005 MG/L				
RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
0100 TURBIDITY Detection: 0.04 NTU	2130B	06/15/2020 8.45 AM 06/15/2020 8.45 AM	06/20/2020	