



# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/27/2020 11.11 AM

Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 05/27/2020

Sampling Pt: TCR\_RT Redacted

Address: 113 CHANDLER ST MILTON DE 19968 OT

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S925790 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

PH=6.86

Field Results Free Chlorine: 0.660 Total Chlorine: 1.560

pH: Temperature:

Flow Rate: Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	05/28/2020 3.44 PM	05/28/2020 3.44 PM	05/29/2020
Detection: Absent					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	05/28/2020 3.44 PM	05/28/2020 3.44 PM	05/29/2020
Detection: Absent					

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/27/2020 11.11 AM  
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 05/27/2020  
Sampling Pt: TCR\_RT Redacted  
Address: 113 CHANDLER ST MILTON DE 19968 OT  
Sample Type: ROUTINE For Compliance: Yes  
Lab Sample No: S925790 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY  
State Sample No: PH=6.86

---

# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT  
DISTRIBUTION SYSTEM

Sample Collected: 05/27/2020 11.11 AM

Facility Source/Plant : DS001

Redacted

Lab Received: 05/27/2020

Sampling Pt: TCR\_RT

Address: 113 CHANDLER ST MILTON DE 19968 OT

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925790

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

PH=6.86

### Field Results

Free Chlorine: 0.660

Total Chlorine: 1.560

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	05/28/2020 3.44 PM	05/28/2020 3.44 PM	05/29/2020
Detection: Absent					
RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	05/28/2020 3.44 PM	05/28/2020 3.44 PM	05/29/2020
Detection: Absent					

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/27/2020 11.11 AM  
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 05/27/2020  
Sampling Pt: TCR\_RT Redacted  
Address: 113 CHANDLER ST MILTON DE 19968 OT  
Sample Type: ROUTINE For Compliance: Yes  
Lab Sample No: S925790 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY  
State Sample No: PH=6.86

---

# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/27/2020 11.30 AM

Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 05/27/2020

Sampling Pt: TCR\_RT Redacted

Address: 610 MULBERRY ST MILTON DE 19968 BS

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S925791 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

PH=6.86

Field Results Free Chlorine: 0.360 Total Chlorine: 0.490

pH: Temperature:

Flow Rate: Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
--------	---------	--------	------------------------------	-------------------	-----------------

3100	COLIFORM (TCR)	9223B-PA	05/28/2020 3.44 PM	05/28/2020 3.44 PM	05/29/2020
------	----------------	----------	--------------------	--------------------	------------

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
--------	---------	--------	------------------------------	-------------------	-----------------

3014	E. COLI	9223B-PA	05/28/2020 3.44 PM	05/28/2020 3.44 PM	05/29/2020
------	---------	----------	--------------------	--------------------	------------

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/27/2020 11.30 AM  
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 05/27/2020  
Sampling Pt: TCR\_RT Redacted  
Address: 610 MULBERRY ST MILTON DE 19968 BS  
Sample Type: ROUTINE For Compliance: Yes  
Lab Sample No: S925791 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY  
State Sample No: PH=6.86

---

# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 05/27/2020 11.30 AM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 05/27/2020

Sampling Pt: TCR\_RT

Redacted

Address:

610 MULBERRY ST MILTON DE 19968 BS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925791

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

PH=6.86

### Field Results

Free Chlorine: 0.360

Total Chlorine: 0.490

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3100 COLIFORM (TCR)

9223B-PA

05/28/2020 3.44 PM 05/28/2020 3.44 PM

05/29/2020

Detection: Absent

RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3014 E. COLI

9223B-PA

05/28/2020 3.44 PM 05/28/2020 3.44 PM

05/29/2020

Detection: Absent

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 05/27/2020

11.30 AM

Facility Source/Plant: DS001

DISTRIBUTION SYSTEM

Lab Received: 05/27/2020

Sampling Pt: TCR\_RT

Redacted

Address: 610 MULBERRY ST MILTON DE 19968 BS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925791

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

PH=6.86



# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT  
DISTRIBUTION SYSTEM

Sample Collected: 05/27/2020 11.50 AM

Facility Source/Plant : DS001

Redacted

Lab Received: 05/27/2020

Sampling Pt: TCR\_RT

Address: 701 FEDERAL ST MILTON DE 19968 BS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925792

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

PH=6.86

### Field Results

Free Chlorine: 0.330

Total Chlorine: 0.380

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	05/28/2020 3.44 PM	05/28/2020 3.44 PM	05/29/2020
Detection: Absent					
RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	05/28/2020 3.44 PM	05/28/2020 3.44 PM	05/29/2020
Detection: Absent					

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/27/2020 11.50 AM  
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 05/27/2020  
Sampling Pt: TCR\_RT Redacted  
Address: 701 FEDERAL ST MILTON DE 19968 BS  
Sample Type: ROUTINE For Compliance: Yes  
Lab Sample No: S925792 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY  
State Sample No: PH=6.86

---

# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 05/27/2020 11:50 AM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 05/27/2020

Sampling Pt: TCR\_RT

Redacted

Address: 701 FEDERAL ST MILTON DE 19968 BS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925792

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

PH=6.86

### Field Results

Free Chlorine: 0.330

Total Chlorine: 0.380

pH:

Temperature:

Flow Rate:

Turbidity:

### RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3100 COLIFORM (TCR)

9223B-PA

05/28/2020 3:44 PM 05/28/2020 3:44 PM

05/29/2020

Detection: Absent

### RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3014 E. COLI

9223B-PA

05/28/2020 3:44 PM 05/28/2020 3:44 PM

05/29/2020

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/27/2020 11.50 AM  
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 05/27/2020  
Sampling Pt: TCR\_RT Redacted  
Address: 701 FEDERAL ST MILTON DE 19968 BS  
Sample Type: ROUTINE For Compliance: Yes  
Lab Sample No: S925792 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY  
State Sample No:  
PH=6.86

---

# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/27/2020 12:10 PM

Facility Source/Plant: DS001 DISTRIBUTION SYSTEM Lab Received: 05/27/2020

Sampling Pt: TCR\_RT Redacted

Address: 210 FRONT ST MILTON DE 19968 US

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S925793 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

PH=6.86

Field Results Free Chlorine: 0.320

pH: Total Chlorine: 0.340

Flow Rate: Temperature:

RESULT Analyte Method Analysis Start and End Dates State Notified On PWS Notified On

3100 COLIFORM (TCR) 9223B-PA 05/28/2020 3:44 PM 05/28/2020 3:44 PM 05/29/2020

Detection: Absent

RESULT Analyte Method Analysis Start and End Dates State Notified On PWS Notified On

3014 E. COLI 9223B-PA 05/28/2020 3:44 PM 05/28/2020 3:44 PM 05/29/2020

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/27/2020 12.10 PM  
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 05/27/2020  
Sampling Pt: TCR\_RT Redacted  
Address: 210 FRONT ST MILTON DE 19968 US  
Sample Type: ROUTINE For Compliance: Yes  
Lab Sample No: S925793 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY  
State Sample No: PH=6.86

---

# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT  
DISTRIBUTION SYSTEM

Sample Collected: 05/27/2020 12.10 PM

Facility Source/Plant : DS001

Redacted

Lab Received: 05/27/2020

Sampling Pt: TCR\_RT

Address: 210 FRONT ST MILTON DE 19968 US

Sample Type: ROUTINE

For Compliance: Yes

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

Lab Sample No: S925793

State Sample No: PH=6.86

### Field Results

Free Chlorine: 0.320

Total Chlorine: 0.340

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	05/28/2020 3.44 PM	05/28/2020 3.44 PM	05/29/2020
Detection: Absent					
RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	05/28/2020 3.44 PM	05/28/2020 3.44 PM	05/29/2020
Detection: Absent					

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/27/2020 12.10 PM  
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 05/27/2020  
Sampling Pt: TCR\_RT Redacted  
Address: 210 FRONT ST MILTON DE 19968 US  
Sample Type: ROUTINE For Compliance: Yes  
Lab Sample No: S925793 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY  
State Sample No: PH=6.86

---



# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 05/27/2020 12.25 PM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 05/27/2020

Sampling Pt: TCR\_RT

Redacted

Address: 207 FRONT ST MILTON DE 19968 OTHER WELL 5 SAMPLE POINT

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925794

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

PH=5.60

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	05/28/2020 3.44 PM - 05/28/2020 3.44 PM	05/29/2020	

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	05/28/2020 3.44 PM - 05/28/2020 3.44 PM	05/29/2020	

Detection: Absent



# Drinking Water Watch

## Total Coliform Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/27/2020 12.25 PM

Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 05/27/2020

Sampling Pt: TCR\_RT Redacted

Address: 207 FRONT ST MILTON DE 19968 OTHER WELL 5 SAMPLE POINT

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S925794 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

PH=5.60

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	05/28/2020 3.44 PM - 05/28/2020 3.44 PM	05/29/2020	

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	05/28/2020 3.44 PM - 05/28/2020 3.44 PM	05/29/2020	

Detection: Absent

# Drinking Water Watch

## Inorganic Chemicals Sample Report

**Water System:** DE0000629      **MILTON WATER DEPARTMENT**      **Sample Collected:** 05/27/2020      **11.11 AM**  
**Facility Source/Plant:** TP001      **WELL #2, 3 & 4 TREATMENT PLANT**      **Lab Received:** 05/27/2020  
**Sampling Pt:** DEP001      **Redacted**  
**Address:** 113 CHANDLER ST MILTON DE 19968  
**Sample Type:** ROUTINE      **For Compliance:** Yes  
**Lab Sample No:** S925789      **Laboratory:** DE017      **DELAWARE PUBLIC HEALTH LABORATORY**  
**State Sample No:**

**Field Results**  
**Free Chlorine:** 0.660      **Total Chlorine:** 1.560  
**pH:** 6.9      **Temperature:**  
**Flow Rate:**      **Turbidity:**

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1055 SULFATE	300.0	05/28/2020 9.05 AM - 05/28/2020 9.05 AM	05/29/2020	
<b>Detection:</b> 12.4183 MG/L				

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1041 NITRITE	300.0	05/28/2020 9.05 AM - 05/28/2020 9.05 AM	05/29/2020	
<b>Detection:</b> < 0.1 MG/L				

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/27/2020 11.11 AM  
 Facility Source/Plant: TP001 WELL #2, 3 & 4 TREATMENT PLANT Lab Received: 05/27/2020  
 Sampling Pt: DEP001 Redacted  
 Address: 113 CHANDLER ST MILTON DE 19968  
 Sample Type: ROUTINE For Compliance: Yes  
 Lab Sample No: S925789 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY  
 State Sample No:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1040	NITRATE	300.0	05/28/2020 9.05 AM	05/28/2020 9.05 AM	05/29/2020
Detection: 4.9725 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1025	FLUORIDE	300.0	05/28/2020 9.05 AM	05/28/2020 9.05 AM	05/29/2020
Detection: 0.16 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1017	CHLORIDE	300.0	05/28/2020 9.05 AM	05/28/2020 9.05 AM	05/29/2020
Detection: 24.1704 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1038	NITRATE-NITRITE				
Detection: 4.9725 MG/L					

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/27/2020 11.11 AM  
Facility Source/Plant : TP001 WELL #2, 3 & 4 TREATMENT PLANT Lab Received: 05/27/2020  
Sampling Pt: DEP001 Redacted  
Address: 113 CHANDLER ST MILTON DE 19968  
Sample Type: ROUTINE For Compliance: Yes  
Lab Sample No: S925789 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY  
State Sample No:

---