

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 01/20/2021 12:38 PM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 01/20/2021

Sampling Pt: TCR_RT

Redacted

Address: 113 CHANDLER ST OT

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925782

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.73

Field Results

Free Chlorine: 1.970

Total Chlorine: 0.820

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	01/21/2021 9:48 AM	01/21/2021 9:48 AM	01/25/2021

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	01/21/2021 9:48 AM	01/21/2021 9:48 AM	01/25/2021

Detection: Absent

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 01/20/2021 12.38 PM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 01/20/2021

Sampling Pt: TCR_RT

Redacted

Address: 113 CHANDLER ST OT

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925782

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.73

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 01/20/2021 12:55 PM

Facility Source/Plant: DS001

DISTRIBUTION SYSTEM

Lab Received: 01/20/2021

Sampling Pt: TCR_RT

Redacted

Address: 610 MULBERRY ST BS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925783

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.73

Field Results Free Chlorine: 0.570

Total Chlorine: 0.810

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	01/21/2021 9:48 AM	01/21/2021 9:48 AM	01/25/2021

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	01/21/2021 9:48 AM	01/21/2021 9:48 AM	01/25/2021

Detection: Absent

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 01/20/2021 12.55 PM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 01/20/2021

Sampling Pt: TCR_RT

Redacted

Address: 610 MULBERRY ST BS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925783

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.73

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 01/20/2021 1.12 PM

Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 01/20/2021

Sampling Pt: TCR_RT Redacted

Address: 701 FEDERAL ST BS

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S925784 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.72

Field Results Free Chlorine: 0.900 Total Chlorine: 1.100

pH: Temperature:

Flow Rate: Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	01/21/2021 9.48 AM	01/21/2021 9.48 AM	01/25/2021

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	01/21/2021 9.48 AM	01/21/2021 9.48 AM	01/25/2021

Detection: Absent

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 01/20/2021 1.12 PM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 01/20/2021

Sampling Pt: TCR_RT

Redacted

Address: 701 FEDERAL ST BS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925784

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.72

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 01/20/2021 1.25 PM

Facility Source/Plant: DS001

DISTRIBUTION SYSTEM

Lab Received: 01/20/2021

Sampling Pt: TCR_RT

Redacted

Address: 321 MARINERS CIR OT

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925785

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.72

Field Results Free Chlorine: 0.740

Total Chlorine: 0.930

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	01/21/2021 9.48 AM 01/21/2021 9.48 AM	01/25/2021	

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	01/21/2021 9.48 AM 01/21/2021 9.48 AM	01/25/2021	

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 01/20/2021 1.25 PM
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 01/20/2021
Sampling Pt: TCR_RT Redacted
Address: 321 MARINERS CIR OT
Sample Type: ROUTINE For Compliance: Yes
Lab Sample No: S925785 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
State Sample No:
pH 6.72

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 01/20/2021 1:54 PM

Facility Source/Plant: DS001

DISTRIBUTION SYSTEM

Lab Received: 01/20/2021

Sampling Pt: TCR_RT

Redacted

Address: 210 FRONT ST US

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925786

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:
pH 6.73

Field Results

Free Chlorine: 0.860

Total Chlorine: 1.210

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	01/21/2021 9:48 AM	01/21/2021 9:48 AM	01/25/2021

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	01/21/2021 9:48 AM	01/21/2021 9:48 AM	01/25/2021

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 01/20/2021 1:54 PM
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 01/20/2021
Sampling Pt: TCR_RT Redacted
Address: 210 FRONT ST US
Sample Type: ROUTINE For Compliance: Yes
Lab Sample No: S925786 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
State Sample No: pH 6.73

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 01/20/2021 2.03 PM

Facility Source/Plant: DS001

DISTRIBUTION SYSTEM

Lab Received: 01/20/2021

Sampling Pt: TCR_RT

Redacted

Address: FRONT ST WELL 5 SAMPLE POINT

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925787

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 5.62

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	01/21/2021 9.48 AM	01/21/2021 9.48 AM	01/25/2021

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	01/21/2021 9.48 AM	01/21/2021 9.48 AM	01/25/2021

Detection: Absent

Drinking Water Watch

Inorganic Chemicals Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 01/20/2021 12:37 PM
 Facility Source/Plant: TP001 WELL #2, 4 & 7 TREATMENT PLANT Lab Received: 01/20/2021
 Sampling Pt: DEP001 Redacted
 Address: 113 CHANDLER ST
 Sample Type: ROUTINE For Compliance: Yes
 Lab Sample No: S925781 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
 State Sample No:

Field Results Free Chlorine: 0.820 Total Chlorine: 1.970
 pH: 6.7 Temperature:
 Flow Rate: Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1055	SULFATE	300.0	01/21/2021 9:23 AM 01/21/2021 9:23 AM	01/25/2021	
Detection: 12.6283 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1041	NITRITE	300.0	01/21/2021 9:23 AM 01/21/2021 9:23 AM	01/25/2021	
Detection: < 0.1 MG/L					

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 01/20/2021 12.37 PM
 Facility Source/Plant: TP001 WELL #2, 4 & 7 TREATMENT PLANT Lab Received: 01/20/2021
 Sampling Pt: DEP001 Redacted
 Address: 113 CHANDLER ST
 Sample Type: ROUTINE For Compliance: Yes
 Lab Sample No: S925781 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
 State Sample No:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1040	NITRATE	300.0	01/21/2021 9.23 AM 01/21/2021 9.23 AM	01/25/2021	
Detection: 4.9992 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1025	FLUORIDE	300.0	01/21/2021 9.23 AM 01/21/2021 9.23 AM	01/25/2021	
Detection: 0.2543 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1017	CHLORIDE	300.0	01/21/2021 9.23 AM 01/21/2021 9.23 AM	01/25/2021	
Detection: 25.258 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1038	NITRATE-NITRITE				
Detection: 4.9992 MG/L					

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 01/20/2021 12.37 PM

Facility Source/Plant: TP001

WELL #2, 4 & 7 TREATMENT PLANT

Lab Received: 01/20/2021

Sampling Pt: DEP001

Redacted

Address: 113 CHANDLER ST

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925781

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No: