

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 06/23/2021 8:00 AM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 06/23/2021

Sampling Pt: TCR_SP

Redacted

Address: 113 CHANDLER ST OT

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S895681

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.74

Field Results

Free Chlorine: 0.480

Total Chlorine: 1.180

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3100 COLIFORM (TCR)

9223B-PA

06/23/2021 1:47 PM 06/24/2021 2:10 PM

06/29/2021

Detection: Absent

RESULT Analyte

Method

Analysis Start and End Dates

State Notified On

PWS Notified On

3014 E. COLI

9223B-PA

06/23/2021 1:47 PM 06/24/2021 2:10 PM

06/29/2021

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 06/23/2021 8.00 AM
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 06/23/2021
Sampling Pt: TCR_SP Redacted
Address: 113 CHANDLER ST OT
Sample Type: ROUTINE For Compliance: Yes
Lab Sample No: S895681 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
State Sample No:
pH 6.74

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 06/22/2021 10.04 AM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 06/22/2021

Sampling Pt: TCR_RT

Redacted

Address: 610 MULBERRY ST BS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S629201

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

Field Results Free Chlorine: 0.370

Total Chlorine: 0.510

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	06/23/2021 10:47 AM - 06/23/2021 10:47 AM	06/25/2021	

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	06/23/2021 10:47 AM - 06/23/2021 10:47 AM	06/25/2021	

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 06/22/2021 10.04 AM

Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 06/22/2021

Sampling Pt: TCR_RT Redacted

Address: 610 MULBERRY ST BS

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S629201 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 06/22/2021 10.04 AM
 Facility Source/Plant: DS001 DISTRIBUTION SYSTEM Lab Received: 06/22/2021
 Sampling Pt: TCR_RT Redacted
 Address: 126 BROADKILL RD BS
 Sample Type: ROUTINE For Compliance: Yes
 Lab Sample No: S629203 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
 State Sample No:

Field Results Free Chlorine: 0.360 Total Chlorine: 0.510
 pH:
 Flow Rate: Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	06/23/2021 10.47 AM	06/23/2021 10.47 AM	06/25/2021
Detection: Absent					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	06/23/2021 10.47 AM	06/23/2021 10.47 AM	06/25/2021
Detection: Absent					

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 06/22/2021 10:04 AM
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 06/22/2021
Sampling Pt: TCR_RT Redacted
Address: 126 BROADKILL RD BS
Sample Type: ROUTINE For Compliance: Yes
Lab Sample No: S629203 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
State Sample No:

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT
DISTRIBUTION SYSTEM

Sample Collected: 06/22/2021 11:13 AM

Facility Source/Plant : DS001

Redacted

Lab Received: 06/22/2021

Sampling Pt: TCR_RT

Redacted

Address: 200 WEST SHORE DR OT

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S629204

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

Field Results Free Chlorine: 0.420

Total Chlorine: 0.500

pH: Temperature:

Flow Rate: Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	06/23/2021 10:47 AM - 06/23/2021 10:47 AM	06/25/2021	
Detection: Absent					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	06/23/2021 10:47 AM - 06/23/2021 10:47 AM	06/25/2021	
Detection: Absent					

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 06/22/2021 11.13 AM

Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 06/22/2021

Sampling Pt: TCR_RT Redacted

Address: 200 WEST SHORE DR OT

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S629204 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 06/22/2021 11:38 AM

Facility Source/Plant: DS001 DISTRIBUTION SYSTEM Lab Received: 06/22/2021

Sampling Pt: TCR_RT Redacted

Address: 701 FEDERAL ST KS

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S895677 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

Field Results Free Chlorine: 0.510 Total Chlorine: 0.610

pH: Temperature:

Flow Rate: Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	06/23/2021 10:47 AM - 06/23/2021 10:47 AM	06/25/2021	

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	06/23/2021 10:47 AM - 06/23/2021 10:47 AM	06/25/2021	

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 06/22/2021 11:38 AM

Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 06/22/2021

Sampling Pt: TCR_RT Redacted

Address: 701 FEDERAL ST KS

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S895677 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 06/22/2021 11:49 AM

Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 06/22/2021

Sampling Pt: TCR_RT Redacted

Address: 210 FRONT ST US

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S895678 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

Field Results Free Chlorine: 0.540 Total Chlorine: 0.770

pH: Temperature:

Flow Rate: Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	06/23/2021 10:47 AM - 06/23/2021 10:47 AM	06/25/2021	

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	06/23/2021 10:47 AM - 06/23/2021 10:47 AM	06/25/2021	

Detection: Absent

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 06/22/2021 11:49 AM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 06/22/2021

Sampling Pt: TCR_RT

Redacted

Address: 210 FRONT ST US

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S895678

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:



Delaware Health and Social Services
Division of Public Health Laboratory
30 Sunnyside Road
Smyrna, Delaware 19977

RECEIVED
JUN 29 2021

OFFICE OF DRINKING WATER

LIMS Report #: 810461
Agency: Office of Drinking Water
Label ID (Sample #): S629198 (1515897)
Property Owner/Facility: TP001
PWSID: DE0000629
Water System Name: MILTON WATER DEPARTMENT
Sample Point: DEP001
Sample Location: 113 CHANDLER ST TREATMENT PLANT
Sample Type: RT
Chlorination: Chlorinated

Date Collected: 06/22/2021 9:32 am
Date Received: 06/22/2021 2:32 pm
Collected By: KOERKEL, JOHN
Collector ID: 2714

Sampled pH: 6.74
Free Cl: 0.52
Total Cl: 1.35

Specimen Note:

Test	Result	MCL	Final Date
Sulfate	12.1 mg/L		06/28/2021
Chloride	25.4 mg/L		06/28/2021
Fluoride	1.1 mg/L	<=2.00	06/28/2021
Nitrite (as N)	<0.1 mg/L	<=1.000	06/28/2021
Nitrate (as N)	5.2 mg/L	<=10.00	06/28/2021