



Total Coliform Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/26/2021 8:57 AM

Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 05/26/2021

Sampling Pt: TCR_RT Redacted

Address: 113 CHANDLER ST TREATMENT PLANT 1 - OT

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S925821 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.62

Field Results

Free Chlorine: 0.780 Total Chlorine: 1.580

pH: Temperature:

Flow Rate: Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	05/27/2021 1:57 PM - 05/27/2021 1:57 PM	06/03/2021	
Detection: Absent					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	05/27/2021 1:57 PM - 05/27/2021 1:57 PM	06/03/2021	
Detection: Absent					

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/26/2021 8:57 AM
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 05/26/2021
Sampling Pt: TCR_RT Redacted
Address: 113 CHANDLER ST TREATMENT PLANT 1 - OT
Sample Type: ROUTINE For Compliance: Yes
Lab Sample No: S925821 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
State Sample No: pH 6.62

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 05/26/2021 9.35 AM

Facility Source/Plant: DS001

DISTRIBUTION SYSTEM

Lab Received: 05/26/2021

Sampling Pt: TCR_RT

Redacted

Address: 610 MULBERRYS ST -BS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925822

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.62

Field Results

Free Chlorine: 0.660

Total Chlorine: 0.820

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100 COLIFORM (TCR)	9223B-PA	05/27/2021 1.57 PM	05/27/2021 1.57 PM	06/03/2021

Detection: Absent

RESULT Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014 E. COLI	9223B-PA	05/27/2021 1.57 PM	05/27/2021 1.57 PM	06/03/2021

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/26/2021 9.35 AM
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 05/26/2021
Sampling Pt: TCR_RT Redacted
Address: 610 MULBERRYS ST -BS
Sample Type: ROUTINE For Compliance: Yes
Lab Sample No: S925822 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
State Sample No: pH 6.62

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 05/26/2021 9:52 AM

Facility Source/Plant: DS001

DISTRIBUTION SYSTEM

Lab Received: 05/26/2021

Sampling Pt: TCR_RT

Redacted

Address: 321 MARINERS CIRCLE - OT

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925823

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.62

Field Results Free Chlorine: 0.480

Total Chlorine: 0.700

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	05/27/2021 1:57 PM	05/27/2021 1:57 PM	06/03/2021

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	05/27/2021 1:57 PM	05/27/2021 1:57 PM	06/03/2021

Detection: Absent

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/26/2021 9.52 AM
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 05/26/2021
Sampling Pt: TCR_RT Redacted
Address: 321 MARINERS CIRCLE - OT
Sample Type: ROUTINE For Compliance: Yes
Lab Sample No: S925823 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
State Sample No: pH 6.62

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/26/2021 10.16 AM

Facility Source/Plant: DS001 DISTRIBUTION SYSTEM Lab Received: 05/26/2021

Sampling Pt: TCR_RT Redacted

Address: 200 WEST SHORE DR - OT

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S925824 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.62

Field Results

Free Chlorine: 0.770 Total Chlorine: 1.010

pH: Temperature:

Flow Rate: Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	05/27/2021 1.57 PM	05/27/2021 1.57 PM	06/03/2021
Detection: Absent					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	05/27/2021 1.57 PM	05/27/2021 1.57 PM	06/03/2021
Detection: Absent					

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/26/2021 10.16 AM
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 05/26/2021
Sampling Pt: TCR_RT Redacted
Address: 200 WEST SHORE DR - OT
Sample Type: ROUTINE For Compliance: Yes
Lab Sample No: S925824 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
State Sample No:
PH 6.62



Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/26/2021 10.38 AM

Facility Source/Plant: DS001 DISTRIBUTION SYSTEM Lab Received: 05/26/2021

Sampling Pt: TCR_RT Redacted

Address: 126 BROADKILL RD SUBWAY -MBS

Sample Type: ROUTINE For Compliance: Yes

Lab Sample No: S925825 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY

State Sample No: _____

pH 6.62

Field Results

Free Chlorine: 0.470 Total Chlorine: 0.620

pH: _____ Temperature: _____

Flow Rate: _____ Turbidity: _____

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	05/27/2021 1.57 PM	05/27/2021 1.57 PM	06/03/2021
Detection: Absent					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	05/27/2021 1.57 PM	05/27/2021 1.57 PM	06/03/2021
Detection: Absent					

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/26/2021 10.38 AM
Facility Source/Plant : DS001 DISTRIBUTION SYSTEM Lab Received: 05/26/2021
Sampling Pt: TCR_RT Redacted
Address: 126 BROADKILL RD SUBWAY -MBS
Sample Type: ROUTINE For Compliance: Yes
Lab Sample No: S925825 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
State Sample No: pH 6.62

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 05/26/2021 11.05 AM

Facility Source/Plant: DS001

DISTRIBUTION SYSTEM

Lab Received: 05/26/2021

Sampling Pt: TCR_RT

Redacted

Address: 701 FEDERAL ST -BS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925826

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.62

Field Results Free Chlorine: 0.670

Total Chlorine: 0.820

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	05/27/2021 1:57 PM	05/27/2021 1:57 PM	06/03/2021

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	05/27/2021 1:57 PM	05/27/2021 1:57 PM	06/03/2021

Detection: Absent

Water System: DE00000629

MILTON WATER DEPARTMENT

Sample Collected: 05/26/2021 11.05 AM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 05/26/2021

Sampling Pt: TCR_RT

Redacted

Address: 701 FEDERAL ST-BS

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925826

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.62

Drinking Water Watch

Total Coliform Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 05/26/2021 11:20 AM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 05/26/2021

Sampling Pt: TCR_RT

Redacted

Address: 210 FRONT ST-US

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925827

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.62

Field Results

Free Chlorine: 0.370

Total Chlorine: 0.560

pH:

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3100	COLIFORM (TCR)	9223B-PA	05/27/2021 1:57 PM	05/27/2021 1:57 PM	06/03/2021

Detection: Absent

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
3014	E. COLI	9223B-PA	05/27/2021 1:57 PM	05/27/2021 1:57 PM	06/03/2021

Detection: Absent

Water System: DE00000629

MILTON WATER DEPARTMENT

Sample Collected: 05/26/2021 11.20 AM

Facility Source/Plant : DS001

DISTRIBUTION SYSTEM

Lab Received: 05/26/2021

Sampling Pt: TCR_RT

Redacted

Address: 210 FRONT ST-US

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925827

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

pH 6.62

Drinking Water Watch

Inorganic Chemicals Sample Report

Water System: DE0000629

MILTON WATER DEPARTMENT

Sample Collected: 05/26/2021 8:55 AM

Facility Source/Plant: TP001

WELL #2, 4 & 7 TREATMENT PLANT

Lab Received: 05/26/2021

Sampling Pt: DEP001

Redacted

Address: 113 CHANDLER ST TREATMENT PLANT 1

Sample Type: ROUTINE

For Compliance: Yes

Lab Sample No: S925820

Laboratory: DE017

DELAWARE PUBLIC HEALTH LABORATORY

State Sample No:

Field Results Free Chlorine: 0.780

Total Chlorine: 1.580

pH: 6.6

Temperature:

Flow Rate:

Turbidity:

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1055	SULFATE	300.0	05/27/2021 9:10 AM	06/03/2021	
Detection: 12.4822 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1041	NITRITE	300.0	05/27/2021 9:10 AM	06/03/2021	
Detection: < 0.1 MG/L					

Water System: DE00000629 MILTON WATER DEPARTMENT Sample Collected: 05/26/2021 8:55 AM
 Facility Source/Plant: TP001 WELL #2, 4 & 7 TREATMENT PLANT Lab Received: 05/26/2021
 Sampling Pt: DEP001 Redacted
 Address: 113 CHANDLER ST TREATMENT PLANT 1
 Sample Type: ROUTINE For Compliance: Yes
 Lab Sample No: S925820 Laboratory: DE017
 State Sample No: DELAWARE PUBLIC HEALTH LABORATORY

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1040	NITRATE	300.0	05/27/2021 9:10 AM	05/27/2021 9:10 AM	06/03/2021
Detection: 4.9863 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1025	FLUORIDE	300.0	05/27/2021 9:10 AM	05/27/2021 9:10 AM	06/03/2021
Detection: 0.9949 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1017	CHLORIDE	300.0	05/27/2021 9:10 AM	05/27/2021 9:10 AM	06/03/2021
Detection: 25.1687 MG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
1038	NITRATE-NITRITE				
Detection: 4.9863 MG/L					

Water System: DE0000629 MILTON WATER DEPARTMENT Sample Collected: 05/26/2021 8:55 AM
Facility Source/Plant : TP001 WELL #2, 4 & 7 TREATMENT PLANT Lab Received: 05/26/2021
Sampling Pt: DEP001 Redacted
Address: 113 CHANDLER ST TREATMENT PLANT 1
Sample Type: ROUTINE For Compliance: Yes
Lab Sample No: S925820 Laboratory: DE017 DELAWARE PUBLIC HEALTH LABORATORY
State Sample No:
